



VPC3+S

User Manual

Revision 1.04



Liability Exclusion

We have tested the contents of this document regarding agreement with the hardware and software described. Nevertheless, there may be deviations and we do not guarantee complete agreement. The data in the document is tested periodically, however. Required corrections are included in subsequent versions. We gratefully accept suggestions for improvements.

Copyright

Copyright © profichip GmbH 2009-2012.
All Rights Reserved.

Unless permission has been expressly granted, passing on this document or copying it, or using and sharing its content are not allowed. Offenders will be held liable. All rights reserved, in the event a patent is granted or a utility model or design is registered.

This document is subject to technical changes.

Table of Contents

1	Introduction	5
2	Functional Description	7
2.1	Overview	7
3	Pin Description	9
3.1	Pinout.....	9
3.2	Pin Assignment (Overview)	11
3.2.1	Asynchronous Intel Mode	13
3.2.2	Synchronous Intel Mode	14
3.2.3	Asynchronous Motorola Mode	15
3.2.4	Synchronous Motorola Mode	16
3.2.5	SPI Mode.....	17
3.2.6	I2C Mode	17
4	Memory Organization.....	19
4.1	Overview	19
4.2	Control Parameters (Latches/Registers).....	21
4.3	Organizational Parameters (RAM).....	23
5	ASIC Interface.....	25
5.1	Mode Registers	25
5.1.1	Mode Register 0	25
5.1.2	Mode Register 1	27
5.1.3	Mode Register 2	29
5.1.4	Mode Register 3	31
5.2	Status Register.....	32
5.3	Interrupt Controller	34
5.3.1	Interrupt Request Register	35
5.3.2	Interrupt Acknowledge / Mask Register	38
5.4	Watchdog Timer.....	38
5.4.1	Automatic Baud Rate Identification	39
5.4.2	Baud Rate Monitoring	39
5.4.3	Response Time Monitoring	39
6	PROFIBUS DP Interface	41
6.1	DP Buffer Structure	41
6.2	Description of the DP Services	44
6.2.1	Set_Slave_Add (SAP 55).....	44
6.2.2	Set_Prm (SAP 61)	45
6.2.3	Chk_Cfg (SAP 62)	49
6.2.4	Slave_Diag (SAP 60).....	50
6.2.5	Write_Read_Data / Data_Exchange (Default_SAP).....	52
6.2.6	Global_Control (SAP 58)	56
6.2.7	RD_Input (SAP 56)	57
6.2.8	RD_Output (SAP 57)	57
6.2.9	Get_Cfg (SAP 59).....	58
7	PROFIBUS DP Extensions.....	59

Table of Contents

7.1	Set_(Ext_)Prm (SAP 53 / SAP 61)	59
7.2	PROFIBUS DP-V1	60
7.2.1	Acyclic Communication Relationships	60
7.2.2	Diagnosis Model	63
7.3	PROFIBUS DP-V2	64
7.3.1	DXB (Data eXchange Broadcast)	64
7.3.2	IsoM (Isochronous Mode)	70
7.3.2.1	IsoM-PLL	74
7.3.3	CS (Clock Synchronization)	80
8	Hardware Interface	87
8.1	Universal Processor Bus Interface	87
8.1.1	Overview	87
8.1.2	Parallel Interface Modes	88
8.1.3	SPI Interface Mode	91
8.1.4	I2C Interface Mode	97
8.1.5	Application Examples (Principles)	103
8.1.6	Application with 80C32 (2K Byte RAM Mode)	105
8.1.7	Application with 80C32 (4K Byte RAM Mode)	106
8.1.8	Application with 80C165	107
8.2	Dual Port RAM Controller	107
8.3	UART	108
8.4	ASIC Test	108
9	PROFIBUS Interface	109
9.1	Pin Assignment	109
9.2	Example for the RS485 Interface	110
10	Operational Specifications	111
10.1	Absolute Maximum Ratings	111
10.2	Recommended Operating Conditions	111
10.3	General DC Characteristics	111
10.4	Ratings for the Output Drivers	112
10.5	DC Electrical Characteristics	112
10.6	Timing Characteristics	113
10.6.1	System Bus Interface	113
10.6.2	Timing in the Synchronous Intel Mode	114
10.6.3	Timing in the Asynchronous Intel Mode	116
10.6.4	Timing in the Synchronous Motorola Mode	118
10.6.5	Timing in the Asynchronous Motorola Mode	120
10.6.6	Timing in SPI Interface Mode	123
10.6.7	Timing in I2C Interface Mode	125
10.7	Package Specifications	126
10.7.1	LFBGA48	126
10.7.2	LQFP48	128
10.8	Processing Instructions	130
10.9	Ordering Information	130
	Revision History	133

Profichip's **VPC3+S** is a communication chip with 8-Bit parallel processor interface for intelligent PROFIBUS DP-Slave applications. Alternatively an SPI or I²C interface can be used to communicate with the chip.

The VPC3+S handles the message and address identification, the data security sequences and the protocol processing for PROFIBUS DP. In addition the acyclic communication and alarm messages, described in DP-V1 extension, are supported. Furthermore the slave-to-slave communication Data eXchange Broadcast (DXB) and the Isochronous Bus Mode (IsoM), described in DP-V2 extension, are also provided. For high-precision synchronized motion control applications the chip is equipped with an HW-PLL for IsoM.

Automatic recognition and support of data transmissions rates up to 12 Mbit/s, the integration of the complete PROFIBUS DP protocol, 4K Byte communication RAM and the configurable processor interface are features to create high-performance PROFIBUS DP-Slave applications. The device is to be operated with 3.3V single supply voltage. All inputs are 5V tolerant.

Profichip's **VPC3+S** is another member of profichip's successful VPC3+ family. It is software compatible to other VPC3+ series devices however it offers some unique features like serial processor interfaces, IsoM-PLL and a very small package.

As there are also simple devices in the automation engineering area, such as switches or thermo elements, that do not require a microcontroller for data preprocessing, profichip offers a DP-Slave ASIC with 32 direct input/output bits. The **VPCLS2** handles the entire data traffic independently. No additional microprocessor or firmware is necessary. The VPCLS2 is compatible to existing chips.

Further information about our products or current and future projects is available on our web page: <http://www.profichip.com>.

1 Introduction

Notes:

2.1 Overview

The VPC3+S makes a cost optimized design of intelligent PROFIBUS DP-Slave applications possible.

Due to the very flexible processor interface the VPC3+S supports a broad range of processor types and families. Please check the corresponding chapters of this manual for details. Here are just some common examples:

Intel:	80C31, 80C51, 80X86 and their derivatives
Siemens:	80C166/165/167
Motorola:	HC11-, HC16-, and HC916 types
ARM:	all ARM derivatives with parallel, SPI or I ² C interface

The VPC3+S handles the physical layer 1 and the data link layer 2 of the ISO/OSI-reference-model excluding the analog RS485 drivers.

The **integrated 4K Byte Dual-Port-RAM** serves as an interface between the VPC3+S and the software/application. In case of using 2K Byte the entire memory is divided into 256 segments, with 8 bytes each. Otherwise in the 4K Byte mode the segment base addresses starts at multiple of 16. Addressing by the user is done directly; however, the internal Micro Sequencer (MS) addresses the RAM by means of the so-called base-pointer. The base-pointer can be positioned at the beginning of a segment in the memory. Therefore, all buffers must be located at the beginning of a segment.

If the VPC3+S carries out a DP communication it automatically sets up all DP-SAPs. The various telegram information is made available to the user in separate data buffers (for example, parameter and configuration data). Three buffers are provided for data communication (three for output data and three for input data). As one buffer is always available for communication no resource problems can occur. For optimal diagnosis support, the VPC3+S offers two Diagnosis-Buffers. The user enters the updated diagnosis data into these buffers. One Diagnosis-Buffer is always assigned to the VPC3+S.

The **Bus Interface Unit** is a parameterizable synchronous/asynchronous 8-bit parallel interface for various Intel and Motorola microcontrollers/processors. The user can directly access the internal 2K/4K Byte RAM or the parameter latches and control registers via the 11/12-bit address bus. Alternatively serial standard protocols like SPI or I²C can be used to access the VPC3+S.

Procedure-specific parameters (Station_Address, control bits, etc.) must be transferred to the **Parameter Registers** and to the **Mode Registers** after power-on.

2 Functional Description

The MAC status can be observed at any time in the **Status Register**.

Various events (e.g. various indications, error events, etc.) are entered in the **Interrupt Controller**. These events can be individually enabled via a mask register. Acknowledgement takes place by means of the acknowledge register. The VPC3+S has a common interrupt output.

The integrated **Watchdog Timer** is operated in three different states: BAUD_SEARCH, BAUD_CONTROL and DP_CONTROL.

The **Micro Sequencer** (MS) controls the entire process. It contains the DP-Slave state machine (DP_SM).

The integrated **4K Byte RAM** that operates as a Dual-Port-RAM contains procedure-specific parameters (buffer pointer, buffer lengths, Station_Address, etc.) and the data buffers.

In the **UART**, the parallel data flow is converted into the serial data flow and vice-versa. The VPC3+S is capable of automatically identifying the baud rates (9.6 Kbit/s - 12 Mbit/s).

The **Idle Timer** directly controls the bus times on the serial bus line.

The **IsoM-PLL** provides high-precision synchronization mechanisms as defined in the PROFIBUS DPV2 protocol extension.

3.1 Pinout

The VPC3+S is available in two package versions: LFBGA48 or LQFP48. Several pins are sharing different functions. Which pin function actually applies depends on the interface mode selected by the configuration pins. Four parallel interface modes as well as I2C and SPI mode with configurable clock phase and clock polarity are supported. Please see the following chapters for details.




Figure 3-1: VPC3+S LFBGA48 Pinout (TOP VIEW)

3 Pin Description




Figure 3-2: VPC3+S LQFP48 Pinout (TOP VIEW)

Details about package outlines and dimensions are listed in section 10.7.

3.2 Pin Assignment (Overview)

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Source / Destination
A1	48	AB8	I(S)	Address Bus 8	CPU
		SPI_SCK / I2C_SCK		SPI: Serial Clock / I2C: Serial Clock	
A2	47	XREADY / XDTACK	I(S)/O	READY / DTACK for external CPU	CPU
		SPI_MISO / I2C_SDA		SPI: Master-In-Slave-Out / I2C: Serial Data	
A3	7	GND			
A4	6	VCC			
A5	38	AB3	I	Address Bus 3	CPU
		I2C_SA3		I2C: Slave Address 3	Configuration Pin
A6	37	AB2	I	Address Bus 2	CPU
		I2C_SA2		I2C: Slave Address 2	Configuration Pin
B1	1	AB7	I(S)	Address Bus 7	CPU
		SPI_MOSI		SPI: Master-Out-Slave-In	Configuration Pin
B2	46	AB5	I	Address Bus 5	CPU
		I2C_SA5		I2C: Slave Address 5	Configuration Pin
B3	44	AB9	I	Address Bus 9	CPU
		SPI_CPHA		SPI: Clock Phase	Configuration Pin
B4	41	AB4	I	Address Bus 4	CPU
		I2C_SA4		I2C: Slave Address 4	Configuration Pin
B5	39	AB1	I	Address Bus 1	CPU
		I2C_SA1		I2C: Slave Address 1	Configuration Pin
B6	36	AB0	I	Address Bus 0	CPU
		I2C_SA0		I2C: Slave Address 0	Configuration Pin
C1	3	XCS	I	Chip-Select	CPU
		SPI_XSS		SPI: Slave-Select	
C2	2	AB10	I	Address Bus 10	CPU
		SPI_CPOL		SPI: Clock Polarity	Configuration Pin
C3	45	AB6	I	Address Bus 6	CPU
		I2C_SA6		I2C: Slave Address 6	Configuration Pin
C4	40	SYNC	O	Synchronization Pulse	CPU / Motion Control
C5	35	ALE /AS / AB11	I	Address Latch Enable / Address Strobe / Address Bus 11	CPU
C6	34	XRD / R_W	I	Read / Read-Write	CPU
D1	18	VCC			
D2	5	XTEST0	I	Test Pin 0 (to be connected to VCC)	Test Pin
D3	4	DIVIDER	I	Divider setting for CLKOUT: '0': 12 MHz '1': 24 MHz	Configuration Pin
D4	33	MODE	I	'0': Asynchronous Mode (Parallel Interface Mode) '1': Synchronous Mode (Parallel Interface Mode) '0': SPI (Serial Interface Mode) '1': I2C (Serial Interface Mode)	Configuration Pin

3 Pin Description

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Source / Destination
D5	32	XWR / E_CLOCK / AB11	I	Write / E-Clock (Motorola) / Address Bus 11	CPU
D6	19	GND			
E1	31	GND			
E2	8	CLKOUT	O	Clock Output (12 MHz or 24 MHz)	CPU / System
E3	9	SERMODE	I	'0': Parallel Interface '1': Serial Interface (SPI or I2C)	Configuration Pin
E4	28	MOT/XINT	I	'0': Parallel Interface Intel Format '1': Parallel Interface Motorola Format	Configuration Pin
E5	29	XTEST1	I	Test Pin 1 (to be connected to VCC)	Test Pin
E6	30	VCC			
F1	10	CLK	I(S)	System Clock (48 MHz)	System
F2	11	XDATAEXCH	O	Indicates state 'Data-Exchange' for PROFIBUS DP	LED
F3	16	XCTS	I	Clear-To-Send (for FSK-Modem)	PB-Interface
F4	21	DB2	IO	Data Bus 2	CPU
F5	26	DB0	IO	Data Bus 0	CPU
F6	27	DB1	IO	Data Bus 1	CPU
G1	12	RESET	I(S)	Master-Reset (connect to port pin of CPU)	CPU
G2	15	RXD	I	Receive Data	PB-Interface
G3	17	INT	O	Interrupt	CPU / IRQ Controller
G4	20	DB7	IO	Data Bus 7	CPU
G5	22	DB4	IO	Data Bus 4	CPU
G6	25	DB3	IO	Data Bus 3	CPU
H1	13	TXD	O	Transmit Data	PB-Interface
H2	14	RTS	O	Request-To-Send	PB-Interface
H3	42	VCC			
H4	43	GND			
H5	23	DB6	IO	Data Bus 6	CPU
H6	24	DB5	IO	Data Bus 7	CPU

Figure 3-3: Pin Assignment

Notes: All signals beginning with 'X' are LOW active.

VCC = +3.3 V
GND = 0 V

The assignment of AB11 depends on the parallel interface mode selected.

All unused inputs must be connected to GND.

Input Levels:

I : LVTTTL
I (S) : LVTTTL, Schmitt-Trigger

The following chapters are describing the different processor interface modes supported by the VPC3+S. For every interface mode the settings of the configuration pins and the signals necessary to communicate with the microcontroller are listed. Common signals for all interface types (like clock divider, interrupt and Profibus interface signals are not explicitly listed in this overview.

3.2.1 Asynchronous Intel Mode

In Asynchronous Intel Mode the data and address busses are separate (non-multiplexed). Address line 11 is to be connected to pin C5 of the VPC3+S.

XREADY mechanism is supported.

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Connect to
E3	9	SERMODE	I	'0': Parallel Interface	GND
E4	28	MOT/XINT	I	'0': Intel Format	GND
D4	33	MODE	I	'0': Asynchronous Interface Mode	GND
C5	35	AB11	I	Address Lines Bit 11	CPU Address Bus 11
C2	2	AB10	I	Address Lines Bits [10:0]	CPU Address Bus [10:0]
B3	44	AB9	I		
A1	48	AB8	I(S)		
B1	1	AB7	I(S)		
C3	45	AB6	I		
B2	46	AB5	I		
B4	41	AB4	I		
A5	38	AB3	I		
A6	37	AB2	I		
B5	39	AB1	I		
B6	36	AB0	I		
G4	20	DB7	IO	Data Bus [7:0]	CPU Data Bus [7:0]
H5	23	DB6	IO		
H6	24	DB5	IO		
G5	22	DB4	IO		
G6	25	DB3	IO		
F4	21	DB2	IO		
F6	27	DB1	IO		
F5	26	DB0	IO		
C1	3	XCS	I	Chip-Select Signal (active low)	CPU Chip-Select
D5	32	XWR	I	Write Signal (active low)	CPU Write
C6	34	XRD	I	Read Signal (active low)	CPU Read

Figure 3-4: Interface Configuration: Asynchronous Intel Mode

3 Pin Description

3.2.2 Synchronous Intel Mode

In Synchronous Intel Mode the lower 8 bits of the address lines are multiplexed with the 8 bit data bus DB[7:0]. The upper address lines (bits 10 to 8) need to be connected to the AB[2:0] inputs of the VPC3+S. Address line 11 is to be connected to pin C1 of the VPC3+S.

XREADY mechanism is not supported in this interface mode.

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Connect to
E3	9	SERMODE	I	'0': Parallel Interface	GND
E4	28	MOT/XINT	I	'0': Intel Format	GND
D4	33	MODE	I	'1': Synchronous Interface Mode	VCC
C1	3	AB11	I	Address Bit 11	CPU Address Bus 11
A6	37	AB2	I	Address Bit 10	CPU Address Bus 10
B5	39	AB1	I	Address Bit 9	CPU Address Bus 9
B6	36	AB0	I	Address Bit 8	CPU Address Bus 8
G4	20	DB7	IO	Data Bus [7:0] multiplexed with lower address bits [7:0] ALE used to latch the lower address bits.	CPU Data/Address Bus [7:0]
H5	23	DB6	IO		
H6	24	DB5	IO		
G5	22	DB4	IO		
G6	25	DB3	IO		
F4	21	DB2	IO		
F6	27	DB1	IO		
F5	26	DB0	IO		
C2	2	AB10	I	In Synchronous Intel Mode these inputs are used to generate the internal Chip-Select signal. Chip-Select is active if all inputs are '0'.	Use one (inverted) CPU Address Line for generating the VPC3+S Chip-Select signal. Connect all other inputs to GND.
B3	44	AB9	I		
A1	48	AB8	I(S)		
B1	1	AB7	I(S)		
C3	45	AB6	I		
B2	46	AB5	I		
B4	41	AB4	I		
A5	38	AB3	I		
C5	35	ALE	I	Address Latch Enable The lower address bits [7:0] are latched with the falling edge of ALE	CPU ALE
D5	32	XWR	I	Write Signal (active low)	CPU Write
C6	34	XRD	I	Read Signal (active low)	CPU Read

Figure 3-5: Interface Configuration: Synchronous Intel Mode

3.2.3 Asynchronous Motorola Mode

In Asynchronous Motorola Mode the data and address busses are separate (non-multiplexed). When using HC11 types with a multiplexed bus the address signals AB[7:0] must be generated from the DB[7:0] signals externally. Address line 11 is to be connected to pin D5 of the VPC3+S.

XDTACK mechanism is supported.

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Connect to
E3	9	SERMODE	I	'0': Parallel Interface	GND
E4	28	MOT/XINT	I	'1': Motorola Format	VCC
D4	33	MODE	I	'0': Asynchronous Interface Mode	GND
D5	32	AB11	I	Address Lines Bit 11	CPU Address Bus 11
C2	2	AB10	I	Address Lines Bits [10:0]	CPU Address Bus [10:0]
B3	44	AB9	I		
A1	48	AB8	I(S)		
B1	1	AB7	I(S)		
C3	45	AB6	I		
B2	46	AB5	I		
B4	41	AB4	I		
A5	38	AB3	I		
A6	37	AB2	I		
B5	39	AB1	I		
B6	36	AB0	I		
G4	20	DB7	IO	Data Bus [7:0]	CPU Data Bus [7:0]
H5	23	DB6	IO		
H6	24	DB5	IO		
G5	22	DB4	IO		
G6	25	DB3	IO		
F4	21	DB2	IO		
F6	27	DB1	IO		
F5	26	DB0	IO		
C1	3	XCS	I	Chip-Select Signal (active low)	CPU Chip-Select
C5	35	AS	I	Address Strobe (active low)	CPU Address Strobe
C6	34	R_W	I	Read-Write Signal ('1' = Read)	CPU Read-Write

Figure 3-6: Interface Configuration: Asynchronous Motorola Mode

3 Pin Description

3.2.4 Synchronous Motorola Mode

In Synchronous Motorola Mode the data and address busses are separate (non-multiplexed). When using HC11 types with a multiplexed bus the address signals AB[7:0] must be generated from the DB[7:0] signals externally. Address line 11 is to be connected to pin C5 of the VPC3+S.

XDTACK mechanism is not supported.

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Connect to
E3	9	SERMODE	I	'0': Parallel Interface	GND
E4	28	MOT/XINT	I	'1': Motorola Format	VCC
D4	33	MODE	I	'1': Synchronous Interface Mode	VCC
C5	35	AB11	I	Address Lines Bit 11	CPU Address Bus 11
C2	2	AB10	I	Address Lines Bits [10:0]	CPU Address Bus [10:0]
B3	44	AB9	I		
A1	48	AB8	I(S)		
B1	1	AB7	I(S)		
C3	45	AB6	I		
B2	46	AB5	I		
B4	41	AB4	I		
A5	38	AB3	I		
A6	37	AB2	I		
B5	39	AB1	I		
B6	36	AB0	I		
G4	20	DB7	IO	Data Bus [7:0]	CPU Data Bus [7:0]
H5	23	DB6	IO		
H6	24	DB5	IO		
G5	22	DB4	IO		
G6	25	DB3	IO		
F4	21	DB2	IO		
F6	27	DB1	IO		
F5	26	DB0	IO		
C1	3	XCS	I	Chip-Select Signal (active low)	CPU Chip-Select
D5	32	E_CLOCK	I	E-Clock	CPU E-Clock
C6	34	R_W	I	Read-Write Signal ('1' = Read)	CPU Read-Write

Figure 3-7: Interface Configuration: Synchronous Motorola Mode

3.2.5 SPI Mode

The VPC3+S can be interfaced like an SPI compatible memory device. Depending on the setting of CPOL and CPHA four different SPI modes can be selected. All unused inputs (including DB[7:0]) must be connected to GND.

Ball BGA	Pin QFP	Signal Name	In/Out	Description	Connect to
E3	9	SERMODE	I	'1': Serial Interface	VCC
E4	28	MOT/XINT	I	'0': not used in this mode	GND
D4	33	MODE	I	'0': SPI Mode	GND
C2	2	SPI_CPOL	I	Clock Polarity	VCC or GND
B3	44	SPI_CPHA	I	Clock Phase	VCC or GND
C1	3	SPI_XSS	I	Slave-Select Signal (active low)	CPU Slave-Select
A1	48	SPI_SCK	I(S)	Serial Clock	CPU SCK
B1	1	SPI_MOSI	I	Master-Out-Slave-In (Serial Data Input)	CPU MOSI
A2	47	SPI_MISO	O	Master-In-Slave-Out (Serial Data Output)	CPU MISO

Figure 3-8: Interface Configuration: SPI Mode

3.2.6 I2C Mode

The VPC3+S can be interfaced like an I2C compatible memory device. The VPC3+S is always in slave mode, master mode is not supported. The slave address can be configured by using the AB[6:0] inputs. All unused inputs (including DB[7:0]) must be connected to GND.


Ball BGA	Pin QFP	Signal Name	In/Out	Description	Connect to
E3	9	SERMODE	I	'1': Serial Interface	VCC
E4	28	MOT/XINT	I	'0': not used in this mode	GND
D4	33	MODE	I	'1': I2C Mode	VCC
C3	45	I2C_SA6	I	I2C Slave Address	VCC or GND
B2	46	I2C_SA5	I		VCC or GND
B4	41	I2C_SA4	I		VCC or GND
A5	38	I2C_SA3	I		VCC or GND
A6	37	I2C_SA2	I		VCC or GND
B5	39	I2C_SA1	I		VCC or GND
B6	36	I2C_SA0	I		VCC or GND
A1	48	I2C_SCK	I(S)	Serial Clock	CPU SCK
A2	47	I2C_SDA	I(S) / O	Serial Data Line	CPU SDA

Figure 3-9: Interface Configuration: I2C Mode

3 Pin Description


Notes:

4 Memory Organization




Building of the physical buffer address:

2K Byte Mode:



4K Byte Mode:



4.2 Control Parameters (Latches/Registers)

These cells can be either read-only or write-only. In the Motorola Mode the VPC3+S carries out 'address swapping' for an access to the address locations 00H - 07H (word registers). That is, the VPC3+S internally generates an even address from an odd address and vice-versa.

Address		Name	Bit No.	Significance (Read Access!)
Intel	Mot.			
00H	01H	Int-Req-Reg	7..0	Interrupt Controller Register
01H	00H	Int-Req-Reg	15..8	
02H	03H	Int-Reg	7..0	
03H	02H	Int-Reg	15..8	
04H	05H	Status-Reg	7..0	Status Register
05H	04H	Status-Reg	15..8	
06H	07H	Mode-Reg 0	7..0	Mode Register 0
07H	06H	Mode-Reg 0	15..8	
08H		Din_Buffer_SM	7..0	Buffer assignment of the DP_Din_Buffer_State_Machine
09H		New_Din_Buffer_Cmd	1..0	The user makes a new DP Din_Buf available in the N state.
0AH		Dout_Buffer_SM	7..0	Buffer assignment of the DP_Dout_Buffer_State_Machine
0BH		Next_Dout_Buffer_Cmd	3..0	The user fetches the last DP Dout_Buf from the N state
0CH		Diag_Buffer_SM	3..0	Buffer assignment for the DP_Diag_Buffer_State_Machine
0DH		New_Diag_Buffer_Cmd	1..0	The user makes a new DP Diag_Buf available to the VPC3+S.
0EH		User_Prm_Data_Okay	1..0	The user positively acknowledges the user parameter setting data of a Set_(Ext_)Prm telegram.
0FH		User_Prm_Data_Not_Okay	1..0	The user negatively acknowledges the user parameter setting data of a Set_(Ext_)Prm telegram.
10H		User_Cfg_Data_Okay	1..0	The user positively acknowledges the configuration data of a Chk_Cfg telegram.
11H		User_Cfg_Data_Not_Okay	1..0	The user negatively acknowledges the configuration data of a Chk_Cfg telegram.
12H		DXBout_Buffer_SM	7..0	Buffer assignment of the DXBout_Buffer_State_Machine
13H		Next_DXBout_Buffer_Cmd	2..0	The user fetches the last DXBout_Buf from the N state
14H		SSA_Buffer_Free_Cmd		The user has fetched the data from the SSA_Buf and enables the buffer again.
15H		Mode-Reg 1	7..0	

Figure 4-2: Assignment of the Internal Parameter-Latches for READ

4 Memory Organization

Address		Name	Bit No.	Significance (Write Access!)
Intel	Mot.			
00H	01H	Int-Req-Reg	7..0	Interrupt-Controller-Register
01H	00H	Int-Req_Reg	15..8	
02H	03H	Int-Ack-Reg	7..0	
03H	02H	Int-Ack-Reg	15..8	
04H	05H	Int-Mask-Reg	7..0	
05H	04H	Int-Mask-Reg	15..8	
06H	07H	Mode-Reg0	7..0	Setting parameters for individual bits
07H	06H	Mode-Reg0	15..8	
08H		Mode-Reg1-S	7..0	
09H		Mode-Reg1-R	7..0	
0AH		WD_BAUD_CONTROL_Val	7..0	Square-root value for baud rate monitoring
0BH		minT _{SDR} _Val	7..0	minT _{SDR} time
0CH		Mode-Reg2	7..0	Mode Register 2
0DH		Sync_PW_Reg	7..0	Sync Pulse Width Register
0EH		Control_Command_Reg	7..0	Control_Command value for comparison with SYNCH telegram
0FH		Group_Select_Reg	7..0	Group_Select value for comparison with SYNCH telegram
10H		Reserved		
11H				
12H		Mode-Reg3	7..0	Mode Register 3
13H		Reserved		
14H				
15H				

Figure 4-3: Assignment of the Internal Parameter-Latches for WRITE

4.3 Organizational Parameters (RAM)

The user stores the organizational parameters in the RAM under the specified addresses. These parameters can be written and read.

Address		Name	Bit No.	Significance
Intel	Mot.			
16H		R_TS_Adr		Setup Station_Address of the VPC3+S
17H		SAP_List_Ptr		Pointer to a RAM address which is preset with FFh or to SAP-List
18H	19H	R_User_WD_Value	7..0	In DP_Mode an internal 16-bit watchdog timer monitors the user.
19H	18H	R_User_WD_Value	15..8	
1AH		R_Len_Dout_Buf		Length of the 3 Dout_Buf
1BH		R_Dout_Buf_Ptr1		Segment base address of Dout_Buf 1
1CH		R_Dout_Buf_Ptr2		Segment base address of Dout_Buf 2
1DH		R_Dout_Buf_Ptr3		Segment base address of Dout_Buf 3
1EH		R_Len_Din_Buf		Length of the 3 Din_Buf
1FH		R_Din_Buf_Ptr1		Segment base address of Din_Buf 1
20H		R_Din_Buf_Ptr2		Segment base address of Din_Buf 2
21H		R_Din_Buf_Ptr3		Segment base address of Din_Buf 3
22H		R_Len_DXBout_Buf		Length of the 3 DXBout_Buf
23H		R_DXBout_Buf_Ptr1		Segment base address of DXBout_Buf 1
24H		R_Len_Diag_Buf1		Length of Diag_Buf 1
25H		R_Len_Diag_Buf2		Length of Diag_Buf 2
26H		R_Diag_Buf_Ptr1		Segment base address of Diag_Buf 1
27H		R_Diag_Buf_Ptr2		Segment base address of Diag_Buf 2
28H		R_Len_Cntrl_Buf1		Length of Aux_Buf 1 and the corresponding control buffer, for example SSA_Buf, Prm_Buf, Cfg_Buf, Read_Cfg_Buf
29H		R_Len_Cntrl_Buf2		Length of Aux_Buf 2 and the corresponding control buffer, for example SSA_Buf, Prm_Buf, Cfg_Buf, Read_Cfg_Buf
2AH		R_Aux_Buf_Sel		Bit array; defines the assignment of the Aux_Buf 1 and 2 to the control buffers SSA_Buf, Prm_Buf, Cfg_Buf
2BH		R_Aux_Buf_Ptr1		Segment base address of Aux_Buf 1
2CH		R_Aux_Buf_Ptr2		Segment base address of Aux_Buf 2
2DH		R_Len_SSA_Data		Length of the input data in the Set_Slave_Address_Buf
2EH		R_SSA_Buf_Ptr		Segment base address of the Set_Slave_Address_Buf
2FH		R_Len_Prm_Data		Length of the input data in the Prm_Buf

4 Memory Organization

Address Intel	Mot.	Name	Bit No.	Significance
30H		R_Prm_Buf_Ptr		Segment base address of the Prm_Buf
31H		R_Len_Cfg_Data		Length of the input data in the Cfg_Buf
32H		R_Cfg_Buf_Ptr		Segment base address of the Cfg_Buf
33H		R_Len_Read_Cfg_Data		Length of the input data in the Read_Cfg_Buf
34H		R_Read_Cfg_Buf_Ptr		Segment base address of the Read_Cfg_Buf
35H		R_Len_DXB_Link_Buf		Length of the DXB_Linktable
36H		R_DXB_Link_Buf_Ptr		Segment base address of the DXB_Link_Buf
37H		R_Len_DXB_Status_Buf		Length of the DXB_Status
38H		R_DXB_Status_Buf_Ptr		Segment base address of the DXB_Status_Buf
39H		R_Real_No_Add_Change		This parameter specifies whether the Station_Address may be changed again later.
3AH		R_Ident_Low		The user sets the parameters for the Ident_Number_Low value.
3BH		R_Ident_High		The user sets the parameters for the Ident_Number_High value.
3CH		R_GC_Command		The Control_Command of Global_Control last received
3DH		R_Len_Spec_Prm_Buf		If parameters are set for the Spec_Prm_Buffer_Mode (see Mode Register 0), this cell defines the length of the Prm_Buf.
3EH		R_DXBout_Buf_Ptr2		Segment base address of DXBout_Buf 2
3FH		R_DXBout_Buf_Ptr3		Segment base address of DXBout_Buf 3

Figure 4-4: Assignment of the Organizational Parameters

5.1 Mode Registers

In the VPC3+S parameter bits that access the controller directly or which the controller directly sets are combined in three Mode Registers (0, 1, 2 and 3).

5.1.1 Mode Register 0

Setting parameters for Mode Register 0 may take place in the Offline state only (for example, after power-on). The VPC3+S may not exit the Offline state until Mode Register 0, all Control and Organizational Parameters are loaded (START_VPC3 = 1 in Mode Register 1).

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
06H (Intel)	Freeze_Supported	Sync_Supported	Early_Rdy	Int_Pol	CS_Supported	WD_Base	Dis_Stop_Control	Dis_Start_Control	Mode Reg 0 7 .. 0 See below for coding

Address	Bit Position								Designation
	15	14	13	12	11	10	9	8	
07H (Intel)	Reserved	PrmCmd_Supported	Spec_Clear_Mode *)	Spec_Prm_Buf_Mode **)	Set_Ext_Prm_Supported	User_Time_Base	EOI_Time_Base	DP_Mode	Mode Reg 0 15 .. 8 See below for coding

*) If Spec_Clear_Mode = 1 (Fail Safe Mode) the VPC3+S will accept Data_Exchange telegrams without any output data (data unit length = 0) in the state DATA-EXCH. The reaction to the outputs can be parameterized in the parameterization telegram.

**) When a large number of parameters have to be transmitted from the DP-Master to the DP-Slave, the Aux-Buffer 1/2 must have the same length as the Parameter-Buffer. Sometimes this could reach the limit of the available memory in the VPC3+S. When Spec_Prm_Buf_Mode = 1 the parameterization data are processed directly in this special buffer and the Aux-Buffers can be held compact.

5 ASIC Interface

Mode Register 0, Low-Byte, Address 06H (Intel):	
bit 7 rw-0	Freeze_Supported: Freeze_Mode support 0 = Freeze_Mode is not supported. 1 = Freeze_Mode is supported
bit 6 rw-0	Sync_Supported: Sync_Mode support 0 = Sync_Mode is not supported. 1 = Sync_Mode is supported.
bit 5 rw-0	Early_Rdy: Early Ready 0 = Normal Ready: Ready is generated when data is valid (write) or when data has been accepted (read). 1 = Ready is generated one clock pulse earlier
bit 4 rw-0	INT_Pol: Interrupt Polarity 0 = The interrupt output is low-active. 1 = The interrupt output is high-active.
bit 3 rw-0	CS_Supported: Enable Clock Synchronization 0 = Clock Synchronization is disabled (default) 1 = Clock Synchronization is enabled
bit 2 rw-0	WD_Base: Watchdog Time Base 0 = Watchdog time base is 10 ms (default state) 1 = Watchdog time base is 1 ms
bit 1 rw-0	Dis_Stop_Control: Disable Stopbit Control 0 = Stop bit monitoring is enabled. 1 = Stop bit monitoring is switched off Set_Prm telegram overwrites this memory cell in the DP_Mode. (Refer to the user specific data.)
bit 0 rw-0	Dis_Start_Control: Disable Startbit Control 0 = Monitoring the following start bit is enabled. 1 = Monitoring the following start bit is switched off Set_Prm telegram overwrites this memory cell in the DP_Mode. (Refer to the user specific data.)

Figure 5-1: Coding of Mode Register 0, Low-Byte

Mode Register 0, High-Byte, Address 07H (Intel):	
bit 15 rw-0	Reserved
bit 14 rw-0	PrmCmd_Supported: PrmCmd support for redundancy 0 = PrmCmd is not supported. 1 = PrmCmd is supported
bit 13 rw-0	Spec_Clear_Mode: Special Clear Mode (Fail Safe Mode) 0 = No special clear mode. 1 = Special clear mode. VPC3+S will accept data telegrams with data unit = 0
bit 12 rw-0	Spec_Prm_Buf_Mode: Special-Parameter-Buffer Mode 0 = No Special-Parameter-Buffer. 1 = Special-Parameter-Buffer mode. Parameterization data will be stored directly in the Special-Parameter-Buffer.
bit 11 rw-0	Set_Ext_Prm_Supported: Set_Ext_Prm telegram support 0 = SAP 53 is deactivated 1 = SAP 53 is activated
bit 10 rw-0	User_Time_Base: Timebase of the cyclical User_Time_Clock-Interrupt 0 = The User_Time_Clock-Interrupt occurs every 1 ms. 1 = The User_Time_Clock-Interrupt occurs every 10 ms.
bit 9 rw-0	EOI_Time_Base: End-of-Interrupt Timebase 0 = The interrupt inactive time is at least 1 μ s long. 1 = The interrupt inactive time is at least 1 ms long
bit 8 rw-0	DP_Mode: DP_Mode enable 0 = DP_Mode is disabled. 1 = DP_Mode is enabled. VPC3+S sets up all DP_SAPs (default configuration!)

Figure 5-2: Coding of Mode Register 0, High-Byte

5.1.2 Mode Register 1

Some control bits must be changed during operation. These control bits are combined in Mode Register 1 and can be set independently of each other (Mode-Reg_1_S) or can be reset independently of each other (Mode-Reg_1_R). Separate addresses are used for setting and resetting. A logical '1' must be written to the bit position to be set or reset.

For example, to set START_VPC3 write a '1' to address 08H, in order to reset this bit, write a '1' to address 09H.

5 ASIC Interface

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
08H	Reserved	Reserved	Res_User_WD	En_Change_Cfg_Buffer	User_LEAVE-MASTER	Go_Offline	EOI	START_VPC3	Mode-Reg_1_S 7..0
09H	Reserved	Reserved	Res_User_WD	En_Change_Cfg_Buffer	User_LEAVE-MASTER	Go_Offline	EOI	START_VPC3	Mode-Reg_1_R 7..0 See below for coding

Mode Register 1, Set, Address 08H:	
bit 7 rw-0	Reserved
bit 6 rw-0	Reserved
bit 5 rw-0	Res_User_WD: Resetting the User_WD_Timer 1 = VPC3+S sets the User_WD_Timer to the parameterized value User_WD_Value. After this action, VPC3+S sets Res_User_WD to '0'.
bit 4 rw-0	En_Change_Cfg_Buffer: Enabling buffer exchange (Config-Buffer for Read_Config-Buffer) 0 = With User_Cfg_Data_Okay_Cmd, the Config-Buffer may not be exchanged for the Read_Config-Buffer. 1 = With User_Cfg_Data_Okay_Cmd, the Config-Buffer must be exchanged for the Read_Config-Buffer.
bit 3 rw-0	User_LEAVE-MASTER. Request to the DP_SM to go to WAIT-PRM. 1 = The user causes the DP_SM to go to WAIT-PRM. After this action, VPC3+ sets User_LEAVE-MASTER to '0' again.
bit 2 rw-0	Go_Offline: Going into the Offline state 1 = After the current request ends, VPC3+S goes to the Offline state and sets Go_Offline to '0' again.
bit 1 rw-0	EOI: End-of-Interrupt 1 = VPC3+S disables the interrupt output and sets EOI to '0' again.
bit 0 rw-0	Start_VPC3: Exiting the Offline state 1 = VPC3+S exits offline and goes to Passive_Idle In addition the Idle Timer and Watchdog Timer are started and 'Go_Offline = 0' is set

Figure 5-3: Coding of Mode Register 1

5.1.3 Mode Register 2

Setting parameters for Mode Register 2 may take place in the Offline State only (like Mode Register 0).

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
	0	0	0	0	0	0	0	1	Reset Value
0CH	4kB_Mode	No_Check_Prm_Reserved	SYNC_Pol	SYNC_Ena	DX_Int_Port	DX_Int_Mode	No_Check_GC_Reserved	GC_Int_Mode	Mode Reg 2 7 .. 0

5 ASIC Interface

Mode Register 2, Address 0CH:	
bit 7 w-0	4KB_Mode: size of internal RAM 0 = 2K Byte RAM (default). 1 = 4K Byte RAM
bit 6 w-0	No_Check_Prm_Reserved: disables checking of the reserved bits in DPV1_Status_2/3 of Set_Prm telegram 0 = reserved bits of a Set_Prm telegram are checked (default). 1 = reserved bits of a Set_Prm telegram are not checked.
bit 5 w-0	SYNC_Pol: polarity of SYNC pulse (for Isochronous Mode only) 0 = negative polarity of SYNC pulse (default) 1 = positive polarity of SYNC pulse
bit 4 w-0	SYNC_Ena: enables generation of SYNC pulse (for Isochronous Mode only) 0 = SYNC pulse generation is disabled (default) 1 = SYNC pulse generation is enabled
bit 3 w-0	DX_Int_Port: Port mode for DX_Out interrupt (ignored if SYNC_Ena set) 0 = DX_Out interrupt is not assigned to port DATAEXCH (default). 1 = DX_Out Interrupt (synchronized to SYNCH telegram) is assigned to port DATAEXCH.
bit 2 w-0	DX_Int_Mode: Mode of DX_out interrupt 0 = DX_Out interrupt is only generated, if Len_Dout_Buf is unequal 0 (default). 1 = DX_Out interrupt is generated after every Data_Exchange telegram
bit 1 w-0	No_Check_GC_Reserved: Disables checking of the reserved bits in Global_Control telegram 0 = reserved bits of a Global_Control telegram are checked (default). 1 = reserved bits of a Global_Control telegram are not checked.
bit 0 w-1	GC_Int_Mode: Controls generation of New_GC_Command interrupt 0 = New_GC_Command interrupt is only generated, if a changed Global_Control telegram is received 1 = New_GC_Command interrupt is generated after every Global_Control telegram (default)

Figure 5-4: Coding of Mode Register 2

5.1.4 Mode Register 3

Setting parameters for Mode Register 3 may take place in the Offline State only (like Mode Register 0).

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
12H	Reserved				PLL_Supported	En_Chk_SSAP	DX_Int_Mode_2	GC_Int_Mode_Ext	Mode Reg 3 7 .. 0

Mode Register 3, Address 12H:	
bit 7 w-0	Reserved
bit 6 w-0	Reserved
bit 5 w-0	Reserved
bit 4 w-0	Reserved
bit 3 w-0	PLL_Supported: Enables IsoM-PLL 0 = PLL is disabled 1 = PLL is enabled; For use of PLL, SYNC_Ena must be set.
bit 2 w-0	En_Chk_SSAP: Evaluation of Source Address Extension 0 = VPC3+ accept any value of S_SAP 1 = VPC3+ only process the received telegram if the S_SAP match to the default values presented by the IEC 61158
bit 1 w-0	DX_Int_Mode_2: Mode of DX_out interrupt 0 = DX_Out interrupt is generated after each Data_Exch telegram 1 = DX_Out interrupt is only generated, if received data is not equal to current data in DX_Out buffer of user
bit 0 w-0	GC_Int_Mode_Ext: extend GC_Int_Mode, works only if GC_Int_Mode=0 0 = GC Interrupt is only generated, if changed GC telegram is received 1 = GC Interrupt is only generated, if GC telegram with changed Control_Command is received

Figure 5-5: Coding of Mode Register 3

5 ASIC Interface

5.2 Status Register

The Status Register shows the current VPC3+S status and can be read only.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
04H (Intel)	WD_State		DP_State		Reserved	Diag_Flag	Reserved	Offline/ Passive_Idle	Status-Reg 7..0 See below for coding
	1	0	1	0					

Address	Bit Position								Designation
	15	14	13	12	11	10	9	8	
05H (Intel)	VPC3+ Release				Baud Rate				Status-Reg 15..8 See below for coding
	3	2	1	0	3	2	1	0	

Status Register, Low-Byte, Address 04H (Intel):	
bit 7,6 r-00	WD_State 1..0: State of the Watchdog State Machine 00 = BAUD_SEARCH state 01 = BAUD_CONTROL state 10 = DP_CONTROL state 11 = Not possible
bit 5,4 r-00	DP_State 1..0: State of the DP State Machine 00 = WAIT-PRM state 01 = WAIT-CFG state 10 = DATA-EXCH state 11 = Not possible
bit 3 r-0	Reserved
bit 2 r-0	Diag_Flag: Status of the Diagnosis-Buffer 0 = The Diagnosis-Buffer had been fetched by the DP-Master. 1 = The Diagnosis-Buffer had not been fetched by the DP-Master yet.
bit 1 r-0	Reserved
bit 0 r-0	Offline/Passive-Idle: Offline-/Passive_Idle state 0 = VPC3+S is in Offline. 1 = VPC3+S is in Passive_Idle.

Figure 5-6: Status Register, Low-Byte

Status Register, High-Byte, Address 05H (Intel):	
bit 15-12 r-1110	VPC3+-Release 3..0 : Release number for VPC3+ 1110
bit 11-8 r-1111	Baud Rate 3..0 : The baud rate found by VPC3+S 0000 = 12,00 Mbit/s 0001 = 6,00 Mbit/s 0010 = 3,00 Mbit/s 0011 = 1,50 Mbit/s 0100 = 500,00 Kbit/s 0101 = 187,50 Kbit/s 0110 = 93,75 Kbit/s 0111 = 45,45 Kbit/s 1000 = 19,20 Kbit/s 1001 = 9,60 Kbit/s 1111 = after reset and during baud rate search Rest = not possible

Figure 5-7: Status Register, High-Byte

5.3 Interrupt Controller

The processor is informed about indication messages and various error events via the interrupt controller. Up to a total of 16 events are stored in the interrupt controller. The events are summed up to a common interrupt output. The controller does not have a prioritization level and does not provide an interrupt vector (not 8259A compatible!).

The controller consists of an Interrupt Request Register (IRR), an Interrupt Mask Register (IMR), an Interrupt Register (IR) and an Interrupt Acknowledge Register (IAR).




Figure 5-8: Block Diagram of Interrupt Controller

Each event is stored in the IRR. Individual events can be suppressed via the IMR. The input in the IRR is independent of the interrupt masks. Events that are not masked in the IMR set the corresponding IR bit and generate the X/INT interrupt via a sum network. The user can set each event in the IRR for debugging.

Each interrupt event that was processed by the microcontroller must be deleted via the IAR (except for New_(Ext_)Prm_Data and New_Cfg_Data). A logical '1' must be written on the specific bit position. If a new event and an acknowledge from the previous event are present at the IRR at the same time, the event remains stored. If the microcontroller enables a mask subsequently, it must be ensured that no prior IRR input is present. To be on the safe side, the position in the IRR must be deleted prior to the enabling of the mask.

Before leaving the interrupt routine, the microprocessor must set the 'end of interrupt bit' (EOI = 1) in Mode Register 1. The interrupt output is switched to inactive with this edge change. If another event occurs, the interrupt output is not activated again until the interrupt inactive time of at least 1 μs or 1 ms expires. This interrupt inactive time can be set via EOI_Time_Base in Mode Register 0. This makes it possible to enter the interrupt routine again when an edge-triggered interrupt input is used.

The polarity of the interrupt output is parameterized via the Int_Pol bit in Mode Register 0. After hardware reset, the output is low-active.

5.3.1 Interrupt Request Register

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
00H (Intel)	DXB_Out	New_Ext_Prm_Data	DXB_Link_Error	User_Timer_Clock	WD_DP_CONTROL_Timeout	Baud_Rate_Detect	Go/Leave_DATA-EXCH	MAC_Reset / Clock_Sync	Int-Req-Reg 7 .. 0 See below for coding

Address	Bit Position								Designation
	15	14	13	12	11	10	9	8	
01H (Intel)	FDL_Ind	Poll_End_Ind	DX_Out	Diag_Buffer_Changed	New_Prm_Data	New_Cfg_Data	New_SSA_Data	New_GC Command	Int-Req-Reg 15 .. 8 See below for coding

5 ASIC Interface

Interrupt-Request-Register, Low-Byte, Address 00H (Intel):	
bit 7 rw-0	DXB_Out: VPC3+S has received a DXB telegram and made the new output data available in the 'N' buffer.
bit 6 rw-0	New_Ext_Prm_Data: The VPC3+S has received a Set_Ext_Prm telegram and made the data available in the Parameter-Buffer.
bit 5 rw-0	DXB_Link_Error: The Watchdog cycle is elapsed and at least one Publisher-Subscriber connection breaks down.
bit 4 rw-0	User_Timer_Clock: The time base for the User_Timer_Clocks is run out (1 / 10ms).
bit 3 rw-0	WD_DP_CONTROL_Timeout: The watchdog timer expired in the DP_CONTROL state.
bit 2 rw-0	Baud_Rate_Detect: The VPC3+S has left the BAUD_SEARCH state and found a baud rate.
bit 1 rw-0	Go/Leave_DATA-EXCH: The DP_SM has entered or exited the DATA-EXCH state.
bit 0 rw-0	MAC_Reset (used if CS_Supported=0): After processing the current request, the VPC3+D has entered the Offline state (by setting the Go_Offline bit). Clock_Sync (used if CS_Supported=1): The VPC3+D has received a Clock_Value telegram or an error occurs. Further differentiation is made in the Clock_Sync-Buffer.

Figure 5-9: Interrupt-Request-Register, Low-Byte

Interrupt Request Register 0, High-Byte, Address 01H (Intel):	
bit 15 rw-0	FDL_Ind: The VPC3+S has received an acyclic service request and made the data available in an Indication-Buffer.
bit 14 rw-0	Poll_End_Ind: The VPC3+S have send the response to an acyclic service.
bit 13 rw-0	DX_Out: The VPC3+S have received a Data_Exchange telegram and made the new output data available in the 'N' buffer.
bit 12 rw-0	Diag_Buffer_Changed: Due to the request made by New_Diag_Cmd, the VPC3+S exchanged the Diagnosis-Buffers and made the old buffer available to the user again.
bit 11 rw-0	New_Prm_Data: The VPC3+S have received a Set_Prm telegram and made the data available in the Parameter-Buffer.
bit 10 rw-0	New_Cfg_Data: The VPC3+S have received a Chk_Cfg telegram and made the data available in the Config-Buffer.
bit 9 rw-0	New_SSA_Data: The VPC3+S have received a Set_Slave_Add telegram and made the data available in the Set_Slave_Add-Buffer.
bit 8 rw-0	New_GC_Command: The VPC3+S have received a Global_Control telegram and stored the Control_Command in the R_GC_Command RAM cell.

Figure 5-10: Interrupt Request Register, High-Byte

5.3.2 Interrupt Acknowledge / Mask Register

The other interrupt controller registers are assigned in the bit positions like the Interrupt Request Register.

Address	Register		Reset state	Assignment
02H / 03H	Interrupt Register (IR)	Readable only	All bits cleared	
04H / 05H	Interrupt Mask Register (IMR)	Writeable, can be changed during operation	All bits set	1 = Mask is set and the interrupt is disabled 0 = Mask is cleared and the interrupt is enabled
02H / 03H	Interrupt Acknowledge Register (IAR)	Writeable, can be changed during operation	All bits cleared	1 = Interrupt is acknowledged and the IRR bit is cleared 0 = IRR bit remains unchanged

Figure 5-11: Interrupt Acknowledge / Mask Register



The New_(Ext_)Prm_Data, New_Cfg_Data interrupts cannot be acknowledged via the Interrupt Acknowledge Register. The relevant state machines clear these interrupts through the user acknowledgements (for example, User_Prm_Data_Okay etc.).

5.4 Watchdog Timer

The VPC3+S is able to identify the baud rate automatically. The state machine is in the BAUD_SEARCH state after each RESET and also after the Watchdog (WD) Timer has expired in the BAUD_CONTROL state.




Figure 5-12: Watchdog State Machine (WD_SM)

5.4.1 Automatic Baud Rate Identification

The VPC3+S starts searching for the transmission rate using the highest baud rate. If no SD1 telegram, SD2 telegram, or SD3 telegram was received completely and without errors during the monitoring time, the search continues using the next lower baud rate.

After identifying the correct baud rate, the VPC3+S switches to the BAUD_CONTROL state and observes the baud rate. The monitoring time can be parameterized (WD_BAUD_CONTROL_Val). The watchdog uses a clock of 100 Hz (10 ms). Each telegram to its own Station_Address received with no errors resets the Watchdog. If the timer expires, the VPC3+S switches to the BAUD_SEARCH state again.

5.4.2 Baud Rate Monitoring

The detected baud rate is permanently monitored in BAUD_CONTROL. The Watchdog is triggered by each error-free telegram to its own Station_Address. The monitoring time results from multiplying twice WD_BAUD_CONTROL_Val (user sets this parameter) by the time base (10 ms). If the timer expires, WD_SM again goes to BAUD_SEARCH. If the user uses the DP protocol (DP_Mode = 1, see Mode Register 0), the watchdog is used for the DP_CONTROL state, after a Set_Prm telegram was received with an enabled response time monitoring (WD_On = 1). The watchdog timer remains in the baud rate monitoring state when the master monitoring is disabled (WD_On = 0). The DP_SM is not reset when the timer expires in the state BAUD_CONTROL. That is, the DP-Slave remains in the DATA-EXCH state, for example.

5.4.3 Response Time Monitoring

The DP_CONTROL state serves as the response time monitoring of the DP-Master (Diag_Master_Add). The used monitoring time results from multiplying both watchdog factors and then multiplying this result with the time base (1 ms or 10 ms):

$$T_{WD} = WD_Base * WD_Fact_1 * WD_Fact_2$$

(See byte 7 of the Set_Prm telegram.)

The user can load the two watchdog factors (WD_Fact_1 and WD_Fact_2) and the time base that represents a measurement for the monitoring time via the Set_Prm telegram with any value between 1 and 255.



EXCEPTION:

The WD_Fact_1 = WD_Fact_2 = 1 setting is not allowed. The circuit does not check this setting.

A monitoring time between 2 ms and 650 s - independent of the baud rate - can be implemented with the allowed watchdog factors.

5 ASIC Interface

If the monitoring time expires, the VPC3+S goes to BAUD_CONTROL state again and generates the WD_DP_CONTROL_Timeout interrupt. In addition, the DP State Machine is reset, that is, it generates the reset states of the buffer management. This operation mode is recommended for the most applications.

If another DP-Master takes over the VPC3+S, the Watchdog State Machine either branches to BAUD_CONTROL (WD_On = 0) or to DP_CONTROL (WD_On = 1).

6.1 DP Buffer Structure

The DP_Mode is enabled in the VPC3+S with 'DP_Mode = 1' (see Mode Register 0). In this mode, the following SAPs are permanently reserved:

Default SAP:	Write and Read data (Data_Exchange)
SAP 53:	Sending extended parameter setting data (Set_Ext_Prm)
SAP 55:	Changing the Station_Address (Set_Slave_Add)
SAP 56:	Reading the inputs (RD_Input)
SAP 57:	Reading the outputs (RD_Output)
SAP 58:	Control commands to the DP-Slave (Global_Control)
SAP 59:	Reading configuration data (Get_Cfg)
SAP 60:	Reading diagnosis information (Slave_Diag)
SAP 61:	Sending parameter setting data (Set_Prm)
SAP 62:	Checking configuration data (Chk_Cfg)

The DP-Slave protocol is completely integrated in the VPC3+S and is handled independently. The user must correspondingly parameterize the ASIC and process and acknowledge received messages. All SAPs are always enabled except the Default SAP, SAP 56, SAP 57 and SAP 58. The remaining SAPs are not enabled until the DP_SM goes into the DATA-EXCH state. The user can disable SAP 55 to not permit changing the Station_Address. The corresponding buffer pointer R_SSA_Buf_Ptr must be set to '00H' for this purpose.

The DP_SAP Buffer Structure is shown in Figure 6-1. The user configures all buffers (length and buffer start) in the Offline state. During operation, the buffer configuration must not be changed, except for the length of the Dout-/Din-Buffers.

The user may still adapt these buffers in the WAIT-CFG state after the configuration telegram (Chk_Cfg). Only the same configuration may be accepted in the DATA-EXCH state.

The buffer structure is divided into the data buffers, Diagnosis-Buffers and the control buffers. Both the output data and the input data have three buffers available with the same length. These buffers are working as changing buffers. One buffer is assigned to the data transfer (D) and one buffer is assigned to the user (U). The third buffer is either in a next state (N) or a free state (F). One of the two states is always unoccupied.

For diagnosis two Diagnosis-Buffers, that can have different lengths, are available. One Diagnosis-Buffer (D) is always assigned to the VPC3+S for sending. The other Diagnosis-Buffer (U) belongs to the user for preprocessing new diagnosis data.




Figure 6-1: DP_SAP Buffer Structure

The VPC3+S first stores the parameter telegrams (Set_Slave_Add and Set_(Ext_)Prm) and the configuration telegram (Chk_Cfg) in Aux-Buffer 1 or Aux-Buffer 2. If the telegrams are error-free, data is exchanged with the corresponding target buffer (Set_Slave_Add-Buffer, Parameter-Buffer and Config-Buffer). Each of the buffers to be exchanged must have the same length. In the R_Aux_Buf_Sel parameter cell (see Figure 6-2) the user defines which Aux_buffers are to be used for the telegrams mentioned

above. The Aux-Buffer 1 must always be available, Aux-Buffer 2 is optional. If the data profiles of these DP telegrams are very different (for example the length of the Set_Prm telegram is significantly larger than the length of the other telegrams) it is suggested to make an Aux-Buffer 2 available (R_Aux_Buf_Sel: Set_Prm = 1) for this telegram. The other telegrams are then read via Aux-Buffer 1 (R_Aux_Buf_Sel: Set_Slave_Adr = 0, Chk_Cfg = 0). If the buffers are too small, the VPC3+S responds with “no resources” (RR)!

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
2AH	0	0	0	0	0	Set_Slave_Add	Chk_Cfg	Set_Prm	R_Aux_Buf_Sel See below for coding

R_Aux_Buf_Sel, Address 2AH:	
bit 7-3	Don't Care: Read as '0'
bit 2	Set_Slave_Adr: Set Slave Address 0 = Aux-Buffer 1 1 = Aux-Buffer 2
bit 1	Chk_Cfg: Check Configuration 0 = Aux-Buffer 1 1 = Aux-Buffer 2
bit 0	Set_Prm: Set (Extended) Parameter 0 = Aux-Buffer 1 1 = Aux-Buffer 2

Figure 6-2: Aux-Buffer Management

The user makes the configuration data (Get_Cfg) available in the Read_Config-Buffer for reading. The Read_Config-Buffer must have the same length as the Config-Buffer.

The RD_Input telegram is serviced from the Din-buffer in the 'D' state and the RD_Output telegram is serviced from the Dout-Buffer in the 'U' state.

All buffer pointers are 8-bit segment addresses, because the VPC3+S have only 8-bit address registers internally. For a RAM access, VPC3+S adds an 8-bit offset address to the segment address shifted by 4 bits (result: 12-bit physical address) in case of 4K Byte RAM or shifted by 3 bits (result: 11-bit physical address) in case of 2K Byte RAM. With regard to the buffer start addresses, this specification results either in a 16-byte or in an 8-byte granularity.

6.2 Description of the DP Services

6.2.1 Set_Slave_Add (SAP 55)

Sequence for the Set_Slave_Add service

The user can disable this service by setting 'R_SSA_Puf_Ptr = 00H'. The Station_Address must then be determined, for example, by reading a DIP-switch or an EEPROM and writing the address in the RAM cell R_TS_Adr.

There must be a non-volatile memory available (for example an external EEPROM) to support this service. It must be possible to store the Station_Address and the Real_No_Add_Change ('True' = FFH) parameter in this EEPROM. After each restart caused by a power failure, the user must read these values from the EEPROM again and write them to the R_TS_Adr und R_Real_No_Add_Change RAM registers.

If SAP55 is enabled and the Set_Slave_Add telegram is received correctly, the VPC3+S enters the pure data in the Aux-Buffer 1/2, exchanges the Aux-Buffer 1/2 for the Set_Slave_Add-Buffer, stores the entered data length in R_Len_SSA_Data, generates the New_SSA_Data interrupt and internally stores the New_Slave_Add as Station_Address and the No_Add_Chg as Real_No_Add_Chg. The user does not need to transfer this changed parameter to the VPC3+S again. After reading the buffer, the user generates the SSA_Buffer_Free_Cmd (read operation on address 14H). This makes the VPC3+S ready again to receive another Set_Slave_Add telegram (for example, from a different DP-Master).

The VPC3+S reacts automatically to errors.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
14H	0	0	0	0	0	0	0	0	SSA_Buf_Free_Cmd

SSA_Buf_Free_Cmd, Address 14H:	
bit 7-0	Don't care: Read as '0'

Figure 6-3: Coding of SSA_Buffer_Free_Command

Structure of the Set_Slave_Add Telegram

The net data are stored as follows in the SSA buffer:

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0									New_Slave_Address
1									Ident_Number_High
2									Ident_Number_Low
3									No_Add_Chg
4 : 243									Rem_Slave_Data additional application specific data

Figure 6-4: Structure of the Set_Slave_Add Telegram

6.2.2 Set_Prm (SAP 61)

Parameter Data Structure

The VPC3+S evaluates the first seven data bytes (without User_Prm_Data), or the first eight data bytes (with User_Prm_Data). The first seven bytes are specified according to the standard. The eighth byte is used for VPC3+S specific characteristics. The additional bytes are available to the application.



If a PROFIBUS DP extension shall be used, the bytes 7-9 are called DPV1_Status and must be coded as described in section 7, "PROFIBUS DP Extensions". Generally it is recommended to start the User_Prm_Data first with byte 10.

6 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	Lock_Req	Unlock_Req	Sync_Req	Freeze_Req	WD_On	Reserved	Reserved	Reserved	Station Status
1									WD_Fact_1
2									WD_Fact_2
3									minT _{SDR}
4									Ident_Number_High
5									Ident_Number_Low
6									Group_Ident
7	DPV1_Enable	Fail_Safe	Publisher_Enable	0	0	WD_Base	Dis_Stop_Control	Dis_Start_Control	Spec_User_Prm_Byte / DPV1_Status_1
8									DPV1_Status_2
9									DPV1_Status_3
10 : 243									User_Prm_Data

Figure 6-5: Format of the Set_Prm Telegram

Spec_User_Prm_Byte / DPV1_Status_1:	
bit 7	DPV1_Enable: 0 = DP-V1 extensions disabled (default) 1 = DP-V1 extensions enabled
bit 6	Fail_Safe: 0 = Fail Safe mode disabled (default) 1 = Fail Safe mode enabled
bit 5	Publisher_Enable: 0 = Publisher function disabled (default) 1 = Publisher function enabled
bit 4-3	Reserved: To be parameterized with '0'
bit 2	WD_Base: Watchdog Time Base 0 = Watchdog time base is 10 ms (default) 1 = Watchdog time base is 1 ms
bit 1	Dis_Stop_Control: Disable Stop bit Control 0 = Stop bit monitoring in the receiver is enabled (default) 1 = Stop bit monitoring in the receiver is disabled
bit 0	Dis_Start_Control: Disable Start bit Control 0 = Start bit monitoring in the receiver is enabled (default) 1 = Start bit monitoring in the receiver is disabled

Figure 6-6: Spec_User_Prm_Byte / DPV1_Status_1



It is recommended not to use the DPV1_Status bytes (bytes 7-9) for user parameter data.

Parameter Data Processing Sequence

In the case of a positive validation of more than seven data bytes, the VPC3+S carries out the following reaction:

The VPC3+S exchanges Aux-Buffer 1/2 (all data bytes are entered here) for the Parameter-Buffer, stores the input data length in R_Len_Prm_Data and triggers the New_Prm_Data interrupt. The user must then check the User_Prm_Data and either reply with User_Prm_Data_Okay_Cmd or with User_Prm_Data_Not_Okay_Cmd. The entire telegram is entered in this buffer. The user parameter data are stored beginning with data byte 8, or with byte 10 if DPV1_Status bytes used.



The user response (User_Prm_Data_Okay_Cmd or User_Prm_Data_Not_Okay_Cmd) clears the New_Prm_Data interrupt. The user cannot acknowledge the New_Prm_Data interrupt in the IAR register.

With the User_Prm_Data_Not_Okay_Cmd message, relevant diagnosis bits are set and the DP_SM branches to WAIT-PRM.

The User_Prm_Data_Okay and User_Prm_Data_Not_Okay acknowledgements are read accesses to defined registers with the relevant signals:

- User_Prm_Finished: No additional parameter telegram is present.
- Prm_Conflict: An additional parameter telegram is present, processing again
- Not_Allowed: Access not permitted in the current bus state

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0EH	0	0	0	0	0	0	↓	↓	User_Prm_Data_Okay
							0	0	User_Prm_Finished
							0	1	Prm_Conflict
							1	1	Not_Allowed

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0FH	0	0	0	0	0	0	↓	↓	User_Prm_ Data_Not_Okay
							0	0	User_Prm_Finished
							0	1	Prm_Conflict
							1	1	Not_Allowed

Figure 6-7: Coding of User_Prm_(Not)_Okay_Cmd

If another Set_Prm telegram is supposed to be received in the meantime, the signal Prm_Conflict is returned for the positive or negative acknowledgement of the first Set_Prm telegram. Then the user must repeat the validation because the VPC3+S has made a new Parameter-Buffer available.

6.2.3 Chk_Cfg (SAP 62)

The user checks the correctness of the configuration data. After receiving an error-free Chk_Cfg telegram, the VPC3+S exchanges the Aux-Buffer 1/2 (all data bytes are entered here) for the Config-Buffer, stores the input data length in R_Len_Cfg_Data and generates the New_Cfg_Data interrupt.

Then the user has to check the User_Config_Data and either respond with User_Cfg_Data_Okay_Cmd or with User_Cfg_Data_Not_Okay_Cmd. The pure data is entered in the buffer in the format of the standard.



The user response (User_Cfg_Data_Okay_Cmd or the User_Cfg_Data_Not_Okay_Cmd response) clears the New_Cfg_Data interrupt. The user cannot acknowledge the New_Cfg_Data in the IAR register.

If an incorrect configuration is reported, several diagnosis bits are changed and the VPC3+S branches to state WAIT-PRM.

For a correct configuration, the transition to DATA-EXCH takes place immediately, if trigger counters for the parameter telegrams and configuration telegrams are at 0. When entering into DATA-EXCH, the VPC3+S also generates the Go/Leave_DATA-EXCH Interrupt.

If the received configuration data from the Config-Buffer is supposed to result in a change to the Read_Config-Buffer (contains the data for the Get_Cfg telegram), the user have to make the new Read_Config data available in the Read_Config-Buffer before the User_Cfg_Data_Okay_Cmd acknowledgement, that is the user has to copy the new configuration data into the Read_Config-Buffer.

During acknowledgement, the user receives information about whether there is a conflict or not. If another Chk_Cfg telegram was supposed to be

6 PROFIBUS DP Extensions

received in the meantime, the user receives the Cfg_Conflict signal during the positive or negative acknowledgement of the first Chk_Cfg telegram. Then the user must repeat the validation, because the VPC3+S have made a new Config-Buffer available.

The User_Cfg_Data_Okay_Cmd and User_Cfg_Data_Not_Okay_Cmd acknowledgements are read accesses to defined memory cells with the relevant Not_Allowed, User_Cfg_Finished, or Cfg_Conflict signals.



If the New_Prm_Data and New_Cfg_Data are supposed to be present simultaneously during start-up, the user must maintain the Set_Prm and then the Chk_Cfg acknowledgement sequence.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
10H	0	0	0	0	0	0	↓	↓	User_Cfg_Data_Okay
							0	0	User_Cfg_Finished
							0	1	Cfg_Conflict
							1	1	Not_Allowed

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
11H	0	0	0	0	0	0	↓	↓	User_Cfg_Data_Not_Okay
							0	0	User_Cfg_Finished
							0	1	Cfg_Conflict
							1	1	Not_Allowed

Figure 6-8: Coding of User_Cfg_(Not)_Okay_Cmd

6.2.4 Slave_Diag (SAP 60)

Diagnosis Processing Sequence

Two buffers are available for diagnosis. These two buffers can have different lengths. One Diagnosis-Buffer, which is sent on a diagnosis request, is always assigned to the VPC3+S. The user can pre-process new diagnosis data in the other buffer parallel. If the new diagnosis data are to be sent, the user issues the New_Diag_Cmd to make the request to exchange the Diagnosis-Buffers. The user receives confirmation of the buffer exchange with the Diag_Buffer_Changed interrupt.

When the buffers are exchanged, the internal Diag_Flag is also set. For an activated Diag_Flag, the VPC3+S responds during the next

Data_Exchange with high-priority response data. That signals the DP-Master that new diagnosis data are present at the DP-Slave. The DP-Master then fetches the new diagnosis data with a Slave_Diag telegram. Then the Diag_Flag is cleared again. However, if the user signals 'Diag.Stat_Diag = 1' (that is static diagnosis, see the structure of the Diagnosis-Buffer), the Diag_Flag still remains activated after the relevant DP-Master has fetched the diagnosis. The user can poll the Diag_Flag in the Status Register to find out whether the DP-Master has already fetched the diagnosis data before the old data is exchanged for the new data.



According to IEC 61158, Static Diagnosis should only be used during start-up.

Status coding for the diagnosis buffers is stored in the Diag_Buffer_SM control parameter. The user can read this cell with the possible codings for both buffers: User, VPC3+, or VPC3+_Send_Mode.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0CH	0	0	0	0	Diag_Buf2		Diag_Buf1		Diag_Buffer_SM

Diag_Buffer_SM, Address 0CH:	
bit 7-4	Don't care: Read as '0'
bit 3-2	Diag_Buf2: Assignment of Diagnosis Buffer 2 00 = Nil 01 = User 10 = VPC3+ 11 = VPC3_Send_Mode
bit 1-0	Diag_Buf1: Assignment of Diagnosis Buffer 1 00 = Nil 01 = User 10 = VPC3+ 11 = VPC3_Send_Mode

Figure 6-9: Diagnosis Buffer Assignment

The New_Diag_Cmd is also a read access to a defined control parameter indicating which Diagnosis-Buffer belongs to the user after the exchange or whether both buffers are currently assigned to the VPC3+S (No_Buffer, Diag_Buf1, Diag_Buf2).

6 PROFIBUS DP Extensions

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0DH	0	0	0	0	0	0	↓	↓	New_Diag_ Buffer_Cmd
							0	0	No_Buffer
							0	1	Diag_Buf1
							1	0	Diag_Buf2

Figure 6-10: Coding of New_Diag_Cmd

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0						Ext_Diag_Overflow	Stat_Diag	Ext_Diag	
1									
2									
3									
4									
5									
6 : n	user input								Ext_Diag_Data (n = max. 243)

Figure 6-11: Format of the Diagnosis-Buffer

The Ext_Diag_Data must be entered into the buffers after the VPC3+S internal diagnosis data. Three different formats are possible here: device-related, ID-related and port-related. If PROFIBUS DP extensions shall be used, the device-related diagnosis is substituted by alarm and status messages. In addition to the Ext_Diag_Data, the buffer length also includes the VPC3+S diagnosis bytes (R_Len_Diag_Buf 1, R_Len_Diag_Buf 2).

6.2.5 Write_Read_Data / Data_Exchange (Default_SAP)

Writing Outputs

The VPC3+S writes the received output data in the 'D' buffer. After an error-free receipt, the VPC3+S shifts the newly filled buffer from 'D' to 'N'. In addition, the DX_Out interrupt is generated. The user now fetches the current output data from 'N'. The buffer changes from 'N' to 'U' with the Next_Dout_Buffer_Cmd, so that the current data can be transmitted to the application by a RD_Output request from a DP-Master.

If the user's evaluation cycle time is shorter than the bus cycle time, the user does not find any new buffers with the next Next_Dout_Buffer_Cmd in 'N'. Therefore, the buffer exchange is omitted. At a 12 Mbit/s baud rate, it is more likely, however, that the user's evaluation cycle time is larger than the bus cycle time. This makes new output data available in 'N' several times before the user fetches the next buffer. It is guaranteed, however, that the user receives the data last received.

For power-on, LEAVE-MASTER and the Global_Control telegram with 'Clear_Data = 1', the VPC3+S deletes the 'D' buffer and then shifts it to 'N'. This also takes place during power-up (entering the WAIT-PRM state). If the user fetches this buffer, he receives U_Buffer_Cleared during the Next_Dout_Buffer_Cmd. If the user is supposed to enlarge the output data buffer after the Chk_Cfg telegram, the user must delete this deviation in the 'N' buffer himself (possible only during the start-up phase in the WAIT-CFG state).

If 'Diag.Sync_Mode = 1', the 'D' buffer is filled but not exchanged with the Data_Exchange telegram. It is exchanged at the next Sync or Unsync command sent by Global_Control telegram.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0AH	F		U		N		D		Dout_Buffer_SM

Dout_Buffer_SM, Address 0AH:	
bit 7-6	F: Assignment of the F-Buffer 00 = Nil 01 = Dout_Buf_Ptr1 10 = Dout_Buf_Ptr2 11 = Dout_Buf_Ptr3
bit 5-4	U: Assignment of the U-Buffer 00 = Nil 01 = Dout_Buf_Ptr1 10 = Dout_Buf_Ptr2 11 = Dout_Buf_Ptr3
bit 3-2	N: Assignment of the N-Buffer 00 = Nil 01 = Dout_Buf_Ptr1 10 = Dout_Buf_Ptr2 11 = Dout_Buf_Ptr3
bit 1-0	D: Assignment of the D-Buffer 00 = Nil 01 = Dout_Buf_Ptr1 10 = Dout_Buf_Ptr2 11 = Dout_Buf_Ptr3

Figure 6-12: Dout-Buffer Management

6 PROFIBUS DP Extensions

When reading the Next_Dout_Buffer_Cmd the user gets the information which buffer ('U' buffer) belongs to the user after the change, or whether a change has taken place at all.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0BH	0	0	0	0	U_Buffer_Cleared	State_U_Buffer	Ind_U_Buffer		Next_Dout_Buf_Cmd See coding below

Next_Dout_Buf_Cmd, Address 0BH:	
bit 7-4	Don't care: Read as '0'
bit 3	U_Buffer_Cleared: User-Buffer-Cleared Flag 0 = U buffer contains data 1 = U buffer is cleared
bit 2	State_U_Buffer: State of the User-Buffer 0 = no new U buffer 1 = new U buffer
bit 1-0	Ind_U_Buffer: Indicated User-Buffer 01 = Dout_Buf_Ptr1 10 = Dout_Buf_Ptr2 11 = Dout_Buf_Ptr3

Figure 6-13: Coding of Next_Dout_Buf_Cmd

The user must clear the 'U' buffer during initialization so that defined (cleared) data can be sent for a RD_Output telegram before the first data cycle.

Reading Inputs

The VPC3+S sends the input data from the 'D' buffer. Prior to sending, the VPC3+S fetches the Din-Buffer from 'N' to 'D'. If no new buffer is present in 'N', there is no change.

The user makes the new data available in 'U'. With the New_Din_Buffer_Cmd, the buffer changes from 'U' to 'N'. If the user's preparation cycle time is shorter than the bus cycle time, not all new input data are sent, but just the most current. At a 12 Mbit/s baud rate, it is more likely, however, that the user's preparation cycle time is larger than the bus cycle time. Then the VPC3+S sends the same data several times in succession.

During start-up, the VPC3+S does not go to DATA-EXCH before all parameter telegrams and configuration telegrams have been acknowledged.

If 'Diag.Freeze_Mode = 1', there is no buffer change prior to sending.

The user can read the status of the state machine cell with the following codings for the four states: Nil, Dout_Buf_Ptr1, Dout_Buf_Ptr2 and Dout_Buf_Ptr3. The pointer for the current data is in the 'N' state.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
08H	F		U		N		D		Din_Buffer_SM

Din_Buffer_SM, Address 08H:	
bit 7-6	F: Assignment of the F-Buffer 00 = Nil 01 = Din_Buf_Ptr1 10 = Din_Buf_Ptr2 11 = Din_Buf_Ptr3
bit 5-4	U: Assignment of the U-Buffer 00 = Nil 01 = Din_Buf_Ptr1 10 = Din_Buf_Ptr2 11 = Din_Buf_Ptr3
bit 3-2	N: Assignment of the N-Buffer 00 = Nil 01 = Din_Buf_Ptr1 10 = Din_Buf_Ptr2 11 = Din_Buf_Ptr3
bit 1-0	D: Assignment of the D-Buffer 00 = Nil 01 = Din_Buf_Ptr1 10 = Din_Buf_Ptr2 11 = Din_Buf_Ptr3

Figure 6-14: Din-Buffer Management

6 PROFIBUS DP Extensions

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
09H	0	0	0	0	0	0	↓	↓	New_Din_Buf_Cmd
							0	1	Din_Buf_Ptr1
							1	0	Din_Buf_Ptr2
							1	1	Din_Buf_Ptr3

Figure 6-15: Coding of New_Din_Buf_Cmd

User_Watchdog_Timer

After start-up (DATA-EXCH state), it is possible that the VPC3+S continually answers Data_Exchange telegrams without the user fetching the received Dout-Buffers or making new Din-Buffers available. If the user processor 'hangs up' the DP-Master would not receive this information. Therefore, a User_Watchdog_Timer is implemented in the VPC3+S.

This User_WD_Timer is an internal 16-bit RAM cell that is started from a user parameterized value R_User_WD_Value and is decremented by the VPC3+S with each received Data_Exchange telegram. If the timer reaches the value 0000H, the VPC3+S goes to the WAIT-PRM state and the DP_SM carries out a LEAVE-MASTER. The user must cyclically set this timer to its start value. Therefore, 'Res_User_WD = 1' must be set in Mode Register 1. Upon receipt of the next Data_Exchange telegram, the VPC3+S again loads the User_WD_Timer to the parameterized value R_User_WD_Value and sets 'Res_User_WD = 0' (Mode Register 1). During power-up, the user must also set 'Res_User_WD = 1', so that the User_WD_Timer is set to its parameterized value.

6.2.6 Global_Control (SAP 58)

The VPC3+S processes the Global_Control telegrams like already described.

The first byte of a valid Global_Control is stored in the R_GC_Command RAM cell. The second telegram byte (Group_Select) is processed internally.

The interrupt behavior regarding to the reception of a Global_Control telegram can be configured via bit 8 of Mode Register 2. The VPC3+S either generates the New_GC_Control interrupt after each receipt of a Global_Control telegram (default) or just in case if the Global_Control differs from the previous one.

The R_GC_Command RAM cell is not initialized by the VPC3+S. Therefore the cell has to be preset with 00H during power-up. The user can read and evaluate this cell.

In order to use Sync and Freeze, these functions must be enabled in the Mode Register 0.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
3CH	Reserved	Reserved	Sync	Unsync	Freeze	Unfreeze	Clear_Data	Reserved	R_GC_Command See below for coding

R_GC_Command, Address 3CH:	
bit 7-6	Reserved
bit 5	Sync: The output data transferred with a Data_Exchange telegram is changed from 'D' to 'N'. The following transferred output data is kept in 'D' until the next Sync command is given.
bit 4	Unsync: The Unsync command cancels the Sync command.
bit 3	Freeze: The input data is fetched from 'N' to 'D' and „frozen“. New input data is not fetched again until the DP-Master sends the next Freeze command.
bit 2	Unfreeze: The Unfreeze command cancels the Freeze command.
bit 1	Clear_Data: With this command, the output data is deleted in 'D' and is changed to 'N'.
bit 0	Reserved

Figure 6-16: Format of the Global_Control Telegram

6.2.7 RD_Input (SAP 56)

The VPC3+S fetches the input data like it does for the Data_Exchange telegram. Prior to sending, 'N' is shifted to 'D', if new input data are available in 'N'. For 'Diag.Freeze_Mode = 1', there is no buffer change.

6.2.8 RD_Output (SAP 57)

The VPC3+S fetches the output data from the Dout_Buffer in 'U'. The user must preset the output data with '0' during start-up so that no invalid data can be sent here. If there is a buffer change from 'N' to 'U' (through the

6 PROFIBUS DP Extensions

Next_Dout_Buffer_Cmd) between the first call-up and the repetition, the new output data is sent during the repetition.

6.2.9 Get_Cfg (SAP 59)

The user makes the configuration data available in the Read_Config-Buffer. For a change in the configuration after the Chk_Cfg telegram, the user writes the changed data in the Config-Buffer, sets 'En_Change_Cfg_buffer = 1' (see Mode Register 1) and the VPC3+S then exchanges the Config-Buffer for the Read_Config-Buffer. If there is a change in the configuration data during operation (for example, for a modular DP systems), the user must return with Go_Offline command (see Mode Register 1) to WAIT-PRM.

7.1 Set_(Ext_)Prm (SAP 53 / SAP 61)

The PROFIBUS DP extensions require three bytes to implement the new parameterization function. The bits of the Spec_User_Prm_Byte are included.

Byte	Bit Position								Designation	
	7	6	5	4	3	2	1	0		
0 : 6										
7	DPV1_ Enable	Fail_Safe	Publisher_ Enable	Reserved	Reserved	WD_Base	Dis_Stop_ Control	Dis_Start_ Control		DPV1_Status_1
8	Enable_ Pull_Plug_Alarm	Enable_ Process_Alarm	Enable_ Diagnostic_Alarm	Enable_ Manufacturer_ Specific_Alarm	Enable_ Status_Alarm	Enable_ Update_Alarm	0	Chk_Cfg_Mode		DPV1_Status_2
9	PrmCmd	0	0	IsoM_Req	Prm_ Structure	Alarm_Mode				DPV1_Status_3
10 : 243										User_Prm_Data

Figure 7-1: Set_Prm with DPV1_Status bytes



If the extensions are used, the bit Spec_Clear_Mode in Mode Register 0 serves as Fail_Safe_required. Therefore it is used for a comparison with the bit Fail_Safe in parameter telegram. Whether the DP-Master supports the Fail_Safe mode or not is indicated by the telegram bit. If the DP-Slave requires Fail_Safe but the DP-Master doesn't the Prm_Fault bit is set.

If the VPC3+S should be used for DXB, IsoM or redundancy mode, the parameterization data must be packed in a Structured_Prm_Data block to distinguish between the User_Prm_Data. The bit Prm_Structure indicates this.

If redundancy should be supported, the PrmCmd_Supported bit in Mode Register 0 must be set.

7 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0									Structured_Length
1									Structure_Typ
2									Slot_Number
3									Reserved
4 : 243									User_Prm_Data

Figure 7-2 : Format of the Structured_Prm_Data block

Additional to the Set_Prm telegram (SAP 61) a Set_Ext_Prm (SAP 53) telegram can be used for parameterization. This service is only available in state WAIT-CFG after the reception of a Set_Prm telegram and before the reception of a Chk_Cfg telegram. The new Set_Ext_Prm telegram simply consists of Structured_Prm_Data blocks.

The new service uses the same buffer handling as described by Set_Prm. By means of the New_Ext_Prm_Data interrupt the user can recognize which kind of telegram is entered in the Parameter-Buffer. Additionally the SAP 53 must be activated by Set_Ext_Prm_Supported bit in Mode Register 0.



The Aux-Buffer for the Set_Ext_Prm is the same as the one for Set_Prm and has to be different from the Chk_Cfg Aux-Buffer. Furthermore the Spec_Prm_Buf_Mode in Mode Register 0 must not be used together with SAP 53.

7.2 PROFIBUS DP-V1

7.2.1 Acyclic Communication Relationships

The VPC3+S supports acyclic communication as described in the DP-V1 specification. Therefore a memory area is required which contains all SAPs needed for the communication. The user must do the initialization of this area (SAP-List) in Offline state. Each entry in the SAP-List consists of 7 bytes. The pointer at address 17H contains the segment base address of the first element of the SAP-List. The last element in the list is always indicated with FFH. If the SAP-List shall not be used, the first entry must be FFH, so the pointer at address 17H must point to a segment base address location that contains FFH.

The new communication features are enabled with DPV1_Enable in the Set_Prm telegram.

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	Response_Sent	SAP_Number							SAP_Number
1									Request_SA
2									Request_SSAP
3									Service_Supported
4									Ind_Buf_Ptr[0]
5									Ind_Buf_Ptr[1]
6									Resp_Buf_Ptr

SAP-List entry:	
Byte 0	Response_Sent: Response-Buffer sent 0 = no Response sent 1 = Response sent SAP_Number: 0 – 51
Byte 1	Request_SA: The source address of a request is compared with this value. At differences, the VPC3+S response with “no service activated” (RS). The default value for this entry is 7FH.
Byte 2	Request_SSAP: The source SAP of a request is compared with this value. At differences, the VPC3+S response with “no service activated” (RS). The default value for this entry is 7FH.
Byte 3	Service_Supported: Indicates the permitted FDL service. 00 = all FDL services allowed
Byte 4	Ind_Buf_Ptr[0]: pointer to Indication-Buffer 0
Byte 5	Ind_Buf_Ptr[1]: pointer to Indication-Buffer 1
Byte 6	Resp_Buf_Ptr: pointer to Response-Buffer

Figure 7-3: SAP-List entry

In addition an Indication- and Response-Buffer are needed. Each buffer consists of a 4-byte header for the buffer management and a data block of configurable length.

7 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	USER	IND	RESP	INUSE					Control
1									Max_Length
2									Length
3									Function Code

SAP-List entry:	
Byte 0	Control: bits for buffer management USER buffer assigned to user IND indication data included in buffer RESP response data included in buffer INUSE buffer assigned to VPC3+S
Byte 1	Max_Length: length of buffer
Byte 2	Length: length of data included in buffer
Byte 3	Function Code: function code of the telegram

Figure 7-4: Buffer Header

Processing Sequence

A received telegram is compared with the values in the SAP-List. If this check is positive, the telegram is stored in an Indication-Buffer with the INUSE bit set. In case of any deviations the VPC3+S responds with “no service activated” (RS) or if no free buffer is available with “no resource” (RR). After finishing the processing of the incoming telegram, the INUSE bit is reset and the bits USER and IND are set by VPC3+S. Now the FDL_Ind interrupt is generated. Polling telegrams do not produce interrupts. The RESP bit indicates response data, provided by the user in the Response-Buffer. The Poll_End_Ind interrupt is set after the Response-Buffer is sent. Also bits RESP and USER are cleared.

DP-Master	PROFIBUS	DP-Slave
	Request to acyclic SAP ->	fill Indication-Buffer
	<- short acknowledgement (SC)	
	Polling telegram to acyclic SAP ->	process data
	<- short acknowledgement (SC)	
	:	
	:	
	:	update Response- Buffer
	Polling telegram to acyclic SAP ->	
	<- Response from acyclic	

Figure 7-5: acyclic communication sequence

VPC3+S	Firmware
set Request_SA / Request_SSA	
set INUSE in Control of Ind_Buf	
write data in Ind_Buf	
clear INUSE and set USER and IND in Control of Ind_Buf	
set FDL_Ind interrupt	
	clear FDL_Ind interrupt
	search for Ind_Buf with IND = 1
	read Ind_Buf
	clear IND in Control of Ind_Buf
	write Response in Resp_Buf
	set RESP in Control of Resp_Buf
check on RESP = 1	
read Resp_Buf	
clear RESP and USER in Control of Resp_Buf	
set Response_Sent	
set Poll_End_Ind interrupt	
	clear Poll_End_Ind interrupt
	search for SAP with Response_Sent = 1
	clear Response_Sent

Figure 7-6: FDL-Interface of VPC3+S (e.g. same Buffer for Indication and Response)

7.2.2 Diagnosis Model

The format of the device related diagnosis data depends on the GSD keyword DPV1_Slave in the GSD. If 'DPV1_Slave = 1', alarm and status messages are used in diagnosis telegrams. Status messages are required by the Data eXchange Broadcast service, for example. Alarm_Ack is used as the other acyclic services.

7.3 PROFIBUS DP-V2

7.3.1 DXB (Data eXchange Broadcast)

The DXB mechanism enables a fast slave-to-slave communication. A DP-Slave that holds input data significant for other DP-Slaves, works as a Publisher. The Publisher can handle a special kind of Data_Exchange request from the DP-Master and sends its answer as a broadcast telegram. Other DP-Slaves which are parameterized as Subscribers can monitor this telegram. A link is opened to the Publisher if the address of the Publisher is registered in the linktable of the Subscriber. If the link has been established correctly, the Subscriber can receive the input data from the Publisher.




Figure 7-7 : Overview DXB

The VPC3+S can handle a maximum of 29 links simultaneously.

Publisher

A Publisher is activated with 'Publisher_Enable = 1' in DPV1_Status_1. The time $\text{min}T_{\text{SDR}}$ must be set to ' $T_{\text{ID1}} = 37 t_{\text{bit}} + 2 T_{\text{SET}} + T_{\text{QUI}}$ '.

All Data_Exchange telegrams containing the function code 7 (Send and Request Data Multicast) are responded with destination address 127. If Publisher mode is not enabled, these requests are ignored.

Subscriber

A Subscriber requires information about the links to its Publishers. These settings are contained in a DXB Linktable or DXB Subscribtable and transferred via the Structured_Prm_Data in a Set_Prm or Set_Ext_Prm telegram. Each Structured_Prm_Data is treated like the User_Prm_Data and therefore to be evaluated by the user. From the received data the user has to generate DXB_Link_Buf and DXB_Status_Buf entries. The watchdog must be enabled to make use of the monitoring mechanism. The user must check this.

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0									Structured_Length
1	0	0	0	0	0	0	1	1	Structure_Type
2	0	0	0	0	0	0	0	0	Slot_Number
3	0	0	0	0	0	0	0	0	Reserved
4	0	0	0	0	0	0	0	1	Version
5									Publisher_Addr
6									Publisher_Length
7									Sample_Offset
8									Sample_Length
9 : 120									further link entries

Figure 7-8: Format of the Structured_Prm_Data with DXB Linktable (specific link is grey scaled)

7 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0									Structured_Length
1	0	0	0	0	0	1	1	1	Structure_Type
2	0	0	0	0	0	0	0	0	Slot_Number
3	0	0	0	0	0	0	0	0	Reserved
4	0	0	0	0	0	0	0	1	Version
5									Publisher_Addr
6									Publisher_Length
7									Sample_Offset
8									Dest_Slot_Number
9									Offset_Data_Area
10									Sample_Length
11 : 120									further link entries

Figure 7-9: Format of the Structured_Prm_Data with DXB Subscribable
(specific link is grey scaled)

The user must copy the link entries of DXB Linktable or DXB Subscribable, without Dest_Slot_Number and Offset_Data_Area, into the DXB_Link_Buf and set R_Len_DXB_Link_Buf. Also the user must enter the default status message in DXB_Status_Buf with the received links and write the appropriate values to R_Len_DXB_Status_Buf. After that, the parameterization interrupt can be acknowledged.

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	0	0	Block_Length						Header_Byte
1	1	0	0	0	0	0	1	1	Status_Type
2	0	0	0	0	0	0	0	0	Slot_Number
3	0	0	0	0	0	0	0	0	Status_Specifier
4									Publisher_Addr
5	Link_Status	Link_Error	0	0	0	0	0	Data_Exist	Link_Status
6 : 61									further link entries

Link_Status:	
bit 7	<p>Link_Status :</p> <p>1 = active, valid data receipt during last monitoring period 0 = not active, no valid data receipt during last monitoring period (DEFAULT)</p>
bit 6	<p>Link_Error:</p> <p>0 = no faulty Broadcast data receipt (DEFAULT) 1 = wrong length, error occurred during reception</p>
bit 0	<p>Data_Exist:</p> <p>0 = no correct Broadcast data receipt during current monitoring period (DEFAULT) 1 = error free reception of Broadcast data during current monitoring period</p>

Figure 7-10: DXB_Link_Status_Buf (specific link is grey scaled)

Processing Sequence

The VPC3+S processes DXBout-Buffers like the Dout-Buffers. The only difference is that the DXBout-Buffers are not cleared by the VPC3+S.

The VPC3+S writes the received and filtered broadcast data in the 'D' buffer. The buffer contains also the Publisher_Address and the Sample_Length. After error-free receipt, the VPC3+S shifts the newly filled buffer from 'D' to 'N'. In addition, the DXBout interrupt is generated. The user now fetches the current output data from 'N'. The buffer changes from 'N' to 'U' with the Next_DXBout_Buffer_Cmd.

7 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0									Publisher_Addr
1									Sample_Length
2 : 246									Sample_Data

Figure 7-11: DXBout-Buffer

When reading the Next_DXBout_buffer_Cmd the user gets the information which buffer ('U' buffer) is assigned to the user after the change, or whether a change has taken place at all.

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
12H	F		U		N		D		DXBout_Buffer_SM

DXBout_Buffer_SM, Address 0AH:	
bit 7-6	F: Assignment of the F-Buffer 00 = Nil 01 = DXBout_Buf_Ptr1 10 = DXBout_Buf_Ptr2 11 = DXBout_Buf_Ptr3
bit 5-4	U: Assignment of the U-Buffer 00 = Nil 01 = DXBout_Buf_Ptr1 10 = DXBout_Buf_Ptr2 11 = DXBout_Buf_Ptr3
bit 3-2	N: Assignment of the N-Buffer 00 = Nil 01 = DXBout_Buf_Ptr1 10 = DXBout_Buf_Ptr2 11 = DXBout_Buf_Ptr3
bit 1-0	D: Assignment of the D-Buffer 00 = Nil 01 = DXBout_Buf_Ptr1 10 = DXBout_Buf_Ptr2 11 = DXBout_Buf_Ptr3

Figure 7-12: DXBout-Buffer Management

Address	Bit Position								Designation
	7	6	5	4	3	2	1	0	
13H	0	0	0	0	0	State_U_ Buffer	Ind_U_ Buffer	Next_DXBout_ Buf_Cmd See coding below	

Next_DXBout_Buf_Cmd, Address 0BH:	
bit 7-3	Don't care: Read as '0'
bit 2	State_U_Buffer: State of the User-Buffer 0 = no new U buffer 1 = new U buffer
bit 1-0	Ind_U_Buffer: Indicated User-Buffer 01 = DXBout_Buf_Ptr1 10 = DXBout_Buf_Ptr2 11 = DXBout_Buf_Ptr3

Figure 7-13: Coding of Next_DXBout_Buf_Cmd

Monitoring

After receiving the DXB data the Link_Status in DXB_Status_Buf of the corresponding Publisher is updated. In case of an error the bit Link_Error is set. If the processing is finished without errors, the bit Data_Exist is set.

In state DATA-EXCH the links are monitored in intervals defined by the parameterized watchdog time. After the monitoring time runs out, the VPC3+S evaluates the Link_Status of each Publisher and updates the bit Link_Status. The timer restarts again automatically.

Event	Link_Status	Link_Error	Data_Exist
valid DXB data receipt		0	1
faulty DXB data receipt	0	1	0
WD_Time elapsed AND Data_Exist = 1	1	0	0
WD_Time elapsed AND Link_Error = 1	0	0	0

Figure 7-14: Link_Status handling



To enable the monitoring of Publisher-Subscriber links the watchdog timer must be enabled in the Set_Prm telegram. The user must check this.

7 PROFIBUS DP Extensions

7.3.2 IsoM (Isochronous Mode)

The IsoM synchronizes DP-Master, DP-Slave and DP-Cycle. The isochronous cycle time starts with the transmission of the SYNCH telegram by the IsoM master. If the IsoM support of the VPC3+S is enabled, a synchronization signal at Pin C4 (SYNC) is generated by each reception of a SYNCH telegram. The SYNCH telegram is a special coded Global_Control request.




Figure 7-15: Telegram sequences in IsoM with one DP-Master (Class 1)

Two operation modes for cyclic synchronization are available in the VPC3+S:

1. Isochronous Mode: Each SYNCH telegram causes an impulse on the SYNC output and a New_GC_Command interrupt. In this mode the IsoM-PLL can be used for compensation of jitter and loss of synchronization.
2. Simple Sync Mode: A Data_Exchange telegram no longer causes a DX_Out interrupt immediately, rather the event is stored in a flag. By a following SYNCH message reception, the DX_Out interrupt and a synchronization signal are generated at the same time. Additionally a New_GC_Command interrupt is produced, as the SYNCH telegram behaves like a regular Global_Control telegram to the DP state machine. If no Data_Exchange telegram precedes the SYNCH telegram, only the New_GC_Command interrupt is generated.

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	0	0						0	Control_Command
1	Group_8 = 1								Group_Select

Figure 7-16: IsoM SYNCH telegram

Each Global_Control is compared with the values that can be adjusted in Control_Command_Reg (0Eh) and Group_Select_Reg (0Fh). If the values are equal a SYNCH telegram will be detected.




Figure 7-17: SYNC-signal and interrupts for synchronization modes (picture only shows the effects by reception of telegrams; time between telegrams is not equal)

Isochronous Mode

To enable the Isochronous Mode in the VPC3+S, bit SYNC_Ena in Mode Register 2 must be set. Additionally the Spec_Clear_Mode in Mode Register 0 must be set. The polarity of the SYNC signal can be adjusted with the SYNC_Pol bit. The register Sync_PW contains a multiplier with the base of 1/12 μ s to adjust the SYNC pulse width. Settings in the Set_Prm telegram are shown below.



The Structured_Prm_Data block IsoM (Structure_Type = 4) is also required for the application. If it is sent by Set_Prm telegram the bit Prm_Structure must be set.

7 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0			Sync_Req = 0	Freeze_Req = 0					Station_Status
1									WD_Fact_1
2									WD_Fact_2
3									minT _{SDR}
4									Ident_Number_High
5									Ident_Number_Low
6	Group_8 = 0								Group_Ident
7		Fail_Safe = 1							DPV1_Status_1
8									DPV1_Status_2
9				IsoM_Req = 1					DPV1_Status_3
10 : 246									User_Prm_Data

Figure 7-18: Format of Set_Prm telegram for IsoM

DP-Slave in an IsoM network

To enable cyclic synchronization via the 'Simple Sync Mode', the bit DX_Int_Port in Mode Register 2 has to be set. Bit SYNC_Ena must not be set. The settings of the pulse polarity are adjusted like described in the IsoM section.

For the parameterization telegram the DP format is used. Though the DPV1_Status bytes 1-3 could be used as User_Prm_Data, it is generally recommended starting the User_Prm_Data at byte 10.

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0			Sync_Req = depends on SYNCH-format	Freeze_Req = depends on SYNCH-format					Station_Status
1									WD_Fact_1
2									WD_Fact_2
3									minT _{SDR}
4									Ident_Number_High
5									Ident_Number_Low
6	Group_8 = 1								Group_Ident
7									DPV1_Status_1
8									DPV1_Status_2
9									DPV1_Status_3
10 : 246									User_Prm_Data

Figure 7-19: Format of Set_Prm for DP-Slave using isochronous cycles

In opposite to IsoM the first DX_Out interrupt is generated after the receipt of a SYNCH telegram. If no Data_Exchange telegram had been received before a SYNCH occurred, no synchronization signal is generated.



For this mechanism the interrupt controller is used. Hence no signal will be generated, if the mask for DX_Out in the IMR is set. Since the synchronization signal is now the DX_Out interrupt, it remains active until the interrupt is acknowledged.

7 PROFIBUS DP Extensions

7.3.2.1 IsoM-PLL

The PLL shall handle following issues:

- The jitter of the SYNCH telegrams has to be smoothed by the PLL. If the jitter exceeds a certain limit, the PLL will recognize a loss of the synchronization.
- SYNCH telegrams lost due to bus disturbances have to be compensated.
- Phase shifts due to line delay between the different DP-slaves may be compensated.
- Generation of a SYNC clock in every slave cycle. The slave application cycle time must be an integer part of DP cycle time.




Figure 7-20: SYNC clock and status signals of PLL

To enable the IsoM-PLL in the VPC3+S, bit PLL_Supported in Mode Register 3 must be set and the IsoM must be parameterized. A Structured_Prm_Data block for IsoM in the parameter telegram contains the configuration values for the PLL.



The PLL can be used in Isochronous Mode only (not in Simple Sync Mode). The user has to take care that the value of SYNC_PW_Reg matches the SYNC cycle time, which could be smaller than the DP cycle time now.

If E_limit is reached, a SYNC clock is generated, too.

Direction	Parameter	Description
IN	Global_Control clock	indicates arriving SYNCH telegram
	PLL start	start and stop of PLL
	SYNC mode	SYNC clock synchronized to Global_Control clock
	SYNC enable	enable SYNC clock after successful synchronization
	specific clock enable	enable only clock0, input or output clock
	SYNC cycle time (T_{SYNC})	period of SYNC clock cycle; shall be an integer part of DP cycle time
	ratio of DP cycle to SYNC cycle (n)	number of SYNC clock cycles per T_{DP}
	E_limit	number of acceptable synchronization errors
	input time (T_{PLL_i})	point in time for actual value acquisition
	output time (T_{PLL_o})	point in time for setpoint transfer
	PLL window (T_{PLL_w})	half the width of the tolerance window
	First_Window	start value of PLL window
	PLL delay time (T_{PLL_D})	delay of the generated SYNC clock, to compensate phase shifts between slaves due to the runtimes of SYNCH telegram
OUT	SYNC clock	output clock of the PLL
	SYNCH error	synchronization errors detected, resynchronization necessary
	PLL synchronized	PLL is synchronized with the DP-Masters SYNCH
	hit display	SYNCH telegram arrived within tolerance window
	clock0 display	SYNC clock coincides with the (expected) Global_Control clock
	input clock display	SYNC clock designated for actual value acquisition
	output clock display	SYNC clock designated for setpoint transfer

Figure 7-21: Inputs and outputs of the PLL

7 PROFIBUS DP Extensions

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	0	0	0	1	1	1	0	0	Structured_Length
1	0	0	0	0	0	1	0	0	Structure_Type
2	0	0	0	0	0	0	0	0	Slot_Number
3	0	0	0	0	0	0	0	0	Reserved
4	0	0	0	0	0	0	0	1	Version
5 : 8	375 / 750 / 1500 / 3000 / 6000 / 12000 (= 31,25 μs / 62,5 μs / 125 μs / 250 μs / 500 μs / 1000 μs)								T _{BASE_DP} : Time Base for T _{DP} (Time Base 1/12 μs)
9 : 10	1..(2 ¹⁶ -1) Note: GSD-Spezifikation: T _{DP_MAX} =32 ms								T _{DP} : DP Cycle Time (Time Base T _{BASE_DP})
11	1..14								T _{MAPC} : Master Application Cycle Time (Time Base T _{DP})
12 : 15	375 / 750 / 1500 / 3000 / 6000 / 12000 (= 31,25 μs / 62,5 μs / 125 μs / 250 μs / 500 μs / 1000 μs)								T _{BASE_IO} : Time Base of T _I , T _O (Time Base 1/12 μs)
16 : 17	0..(2 ¹⁶ -1)								T _I : Instant in Time of the Actual Value Acquisition (Time Base T _{BASE_IO})
18 : 19	0..(2 ¹⁶ -1)								T _O : Instant in Time of the setpoint transfer (Time Base T _{BASE_IO})
20 : 23	0..(2 ³² -1)								T _{DX} : Data_Exchange Time (Time Base 1/12 μs)
24 : 25	1..(2 ¹⁶ -1) (Default: 12)								T _{PLL_W} : PLL Window (Time Base 1/12 μs)
26 : 27	0..(2 ¹⁶ -1) (Default: 0)								T _{PLL_D} : PLL Delay Time (Time Base 1/12 μs)

Figure 7-22: Format of Structured_Prm_Data with IsoM Parameter

The following input parameters have to be calculated by firmware:

- SYNC cycle time:

$$T_{SYNC} = \frac{T_{DP}}{n} = \frac{T_{DP}}{\text{Number_of_SYNC} + 1}$$

- start value of PLL window:

$$\text{First_Window} \geq T_{PLL_W} \cdot n1 + T_{DP} \cdot n2 \quad \text{with } n1 > 1; n2 > 0,0003$$

The base address of the PLL-Buffer depends on the memory mode:

2K Byte mode: 7C0H

4K Byte mode: FC0H

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	reserved		In_Clock_Detect	Out_Clock_Detect	PLL_Synched	GC_Clock_Error	GC_Clock_Detect	GC_Clock_Hit	Status
1	reserved		Enable_In_Clock	Enable_Out_Clock	Enable_GC_Clock	SYNC_Mode	SYNC_Enable	PLL_Start	Command
2 : 3	1..(2 ¹⁶ -1) (Default: 12)								T _{PLL_W} : PLL_Window (Time Base $\frac{1}{12}$ μs)
4 : 5	0..(2 ¹⁶ -1) (Default: 0)								T _{PLL_D} : PLL_Delay_Time (Time Base $\frac{1}{12}$ μs)
6 : 9	1..(2 ³² -1)								T _{SYNC} : SYNC_Cycle_Time (Time Base $\frac{1}{48}$ μs)
10 : 11	reserved					Number_of_SYNC(9:8)		Number_of_SYNC	
	Number_of_SYNC(7:0)								
12 : 15	1..(2 ³² -1)								First_Window (Time Base $\frac{1}{48}$ μs)
16 : 17	reserved					T _{PLL_I} (9:8)		T _{PLL_I} : Input_Time (Time Base T _{SYNC})	
	T _{PLL_I} (7:0)								
18 : 19	reserved					T _{PLL_O} (9:8)		T _{PLL_O} : Output_Time (Time Base T _{SYNC})	
	T _{PLL_O} (7:0)								
20	0..255								E_limit

7 PROFIBUS DP Extensions

PLL Buffer	
GC_Clock_Hit r-0	GC_clock_Hit: The VPC3+ has received a valid 'SYNCH telegram' during the tolerance window.
GC_Clock_Detect r-0	GC_Clock_Detect: Last SYNC signal coincides with the (expected) 'SYNCH telegram'.
GC_Clock_Error r-0	GC_Clock_Error: PLL detects Synchronization Errors and has to be resynchronized.
PLL_synched r-0	PLL_synched: PLL is synchronized with the DP-Masters SYNCH.
Out_Clock_Detect r-0	Out_Clock_Detect: Last SYNC signal coincides with the instant in time of the setpoint transfer.
In_Clock_Detect r-0	In_Clock_Detect: Last SYNC signal coincides with the instant in time of the actual value acquisition.
PLL_Start rw-0	PLL_Start: 0 = PLL is stopped 1 = PLL is started
SYNC_Enable rw-0	SYNC_Enable: 0 = SYNC signal is not enabled 1 = SYNC signal is send to DATAEXCH_N
SYNC_Mode rw-0	SYNC_Mode: 0 = SYNC signal not synchronized to 'SYNCH telegram' 1 = SYNC signal synchronized to 'SYNCH telegram'
Enable_GC_Clock rw-0	Enable_GC_Clock: 0 = generate no SYNC signal coincides with the (expected) 'SYNCH telegram' 1 = generate SYNC signal coincides with the (expected) 'SYNCH telegram'
Enable_Out_Clock rw-0	Enable_Out_Clock: 0 = generate no SYNC signal at T_O 1 = generate SYNC signal at T_O
Enable_In_Clock rw-0	Enable_In_Clock: 0 = generate no SYNC signal at T_I 1 = generate SYNC signal at T_I

Number_of_SYNC rw-0	Number_of_SYNC: Number of SYNC cycles per DP cycle: Number_of_SYNC + 1
T _{PLL_I} rw-0	Input_Time: Number of SYNC cycles from start of DP cycle up to T _I
T _{PLL_O} rw-0	Output_Time: Number of SYNC cycles from start of DP cycle up to T _O
E_limit rw-0	E_limit: Number of acceptable synchronization errors during time interval.

Figure 7-23: Format of the PLL_Buffer



T_I in the Structured_Prm_Data block is the period of time between actual value acquisition and the start of new DP cycle whereas T_{PLL_I} is the period of time from the start of DP cycle to the point of data acquisition.




Figure 7-24: configuration of T_{PLL_O} and T_{PLL_I}

If none of the Enable_xx_Clock bits is set the PLL generates a SYNC clock after every expiration of the slave application cycle (= T_{SYNC}).

VPC3+S	Firmware
	configure DP-Slave for IsoM set PLL_Support
receive Set_(Ext_)Prm set New_(Ext_)Prm_Data interrupt	acknowledge New_(Ext_)Prm_Data interrupt configure PLL
receive SYNCH telegrams	set PLL_Start
synchronization of PLL to GC clock → set hit display	
release clock on SYNC pin	set Sync_Enable

Figure 7-25: Start up of PLL (grey scaled task omitted if SYNC_Mode=0)

7 PROFIBUS DP Extensions

7.3.3 CS (Clock Synchronization)

The Clock Synchronization mechanism synchronizes the time between devices on a PROFIBUS segment. A time master is a DP-Master. The scheme used is a “backwards time based correction”. The knowledge of when a special timer event message was broadcasted is subsequently used to calculate appropriate clock adjustments.

The synchronized time can be used for time stamp mechanism.




Figure 7-26: clock synchronization mechanism

The clock synchronization sequence consists of two messages broadcasted by the time master. When the first message, called `Time_Event`, is received the VPC3+S starts the receive delay timer (t_{RD}). The time master then sends a second message, called `Clock_Value`, which contains the actual time when the `Time_Event` was sent plus the send delay time (t_{SD}). By reception of the second message the `Clock_Sync` interrupt will be generated. To achieve the most accuracy the receive delay timer is running until the user reads the `Clock_Sync`-Buffer.

The VPC3+S only synchronizes the received telegrams, the system time management is done by the user. The user has also to account for the time after the receive delay timer has been read till the update of the system time (t_{PD} : process delay time).

The time for transmission delay (t_{DT} : `CS_Delay_Time`) and the `Clock_Sync_Interval` are communicated to the VPC3+S by a `Structured_Prm_Data` block. The `CS_Delay_Time` is used by the user to calculate the system time: $t_S = \text{Clock_Value_Time_Event} + t_{DT} + t_{RD} + t_{PD}$

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0									Structured_Length
1	0	0	0	0	1	0	0	0	Structure_Type
2	0	0	0	0	0	0	0	0	Slot_Number
3	0	0	0	0	0	0	0	0	Reserved
4 : 5									Clock_Sync_Interval Time Base 10 ms
6 : 13	Seconds ($2^{31}..0$)								CS Delay Time can be omitted
	Fraction Part of Seconds ($2^{31}..0$) Base is $1/(2^{32})$ Seconds								

Figure 7-27: Format of Structured_Prm_Data with Time AR

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0 : 7	Seconds ($2^{31}..0$) since 1.1.1900 0:00,00 or since 7.2.2036 6:28:16 if value < 0x9dff4400								Clock_Value_ Time_Event
	Fraction Part of Seconds ($2^{31}..0$) Base is $1/(2^{32})$ Seconds								
8 : 15	Seconds ($2^{31}..0$) since 1.1.1900 0:00,00 or since 7.2.2036 6:28:16 if value < 0x9dff4400								Clock_Value_ previous_TE
	Fraction Part of Seconds ($2^{31}..0$) Base is $1/(2^{32})$ Seconds								
16	C	CV					reserviert		Clock_Value_Status1
17	ANH	SWT	reserviert	CR		reserviert		SYF	Clock_Value_Status2

Figure 7-28: Format of Clock_Value

Processing Sequence

The Clock_Sync_Interval is a time for monitoring and has to be written into the Clock_Sync-Buffer by the user. The Time Receiver state machine in the VPC3+S is started after this write access. The value for Clock_Sync_Interval is locked until the next LEAVE-MASTER or a new parameterization occurs. In addition it can be unlocked if the user set the Stop_Clock_Sync in Command byte.

7 PROFIBUS DP Extensions

Following to a clock synchronization sequence the Clock_Sync interrupt will be asserted. Further information is contained in the Status byte. If an overflow of the Receive_Delay_Timer occurs the Status byte will be cleared. The VPC3+S cannot write new data to the Clock_Sync-Buffer until the user has acknowledged the Clock_Sync interrupt. Hence to ensure no new data overwrites the buffer, the user should read out the buffer before acknowledging the interrupt.

The base address of the Clock_Sync-Buffer depends on the memory mode:

2K Byte mode: 7E0H

4K Byte mode: FE0H

Byte	Bit Position								Designation
	7	6	5	4	3	2	1	0	
0	reserved						Clock_Sync_Violation	Set_Time	Status
1	reserved					Clock_Value_Check_Ena	Ignore_Cyclic_State_Machine	Stop_Clock_Sync	Command
2	C	CV				reserved			Clock_Value_Status1
3	ANH	SWT	reserved	CR	reserved		SYF	Clock_Value_Status2	
4 : 11	Seconds ($2^{32}-1 \dots 0$) since 1.1.1900 0:00,00 or since 7.2.2036 6:28:16 if value < 9DFF4400H								Clock_Value_Time_Event
	Fraction Part of Seconds ($2^{32}-1 \dots 0$) Base is $1/(2^{32})$ Seconds								
12 : 15	$(2^{32}-1 \dots 0)$ Time Base 1 μ s								Receive_Delay_Time
16 : 23	Seconds ($2^{32}-1 \dots 0$) since 1.1.1900 0:00,00 or since 7.2.2036 6:28:16 if value < 9DFF4400H								Clock_Value_previous_TE
	Fraction Part of Seconds ($2^{32}-1 \dots 0$) Base is $1/(2^{32})$ Seconds								
24 : 25	$(2^{16}-1 \dots 0)$ Time Base 10 ms								Clock_Sync_Interval

Clock_Sync-Buffer	
Status bit 7-2 r-000000	Reserved
Status bit 1 r-0	Clock_Sync_Violation: Wrong telegram or Time period of $2 \cdot T_{CSI}$ expired after reception of Time_Event.
Status bit 0 r-0	Set_Time: The VPC3+D has received a valid 'Clock_Value telegram' and made the data available in the Clock_Sync-Buffer.
Command bit 7-3 r-00000	Reserved
Command bit 2 rw-0	Clock_Value_Check_Ena: 0 = don't evaluate Clock_Value_previous_TE 1 = check Clock_Value_previous_TE with local variable Time_Last_Rcvd
Command bit 1 rw-0	Ignore_Cyclic_State_Machine: 0 = Clock Synchronization stops after the reception of a new Set_Prm or a LEAVE-MASTER 1 = Clock Synchronization continues until the user set Stop_Clock_Sync
Command bit 0 w-0	Stop_Clock_Sync: Stop the Clock Synchronization, in order to write a new T_{CSI} without a previous Set_Prm or LEAVE-MASTER. The Bit is cleared by the Time_Receiver State Machine.
Clock_Value_ Status1 bit 7 r-0	C: Sign of CV 0 = add correction value to Time 1 = subtract correction value to Time
Clock_Value_ Status1 bit 6-2 r-00000	CV: Correction Value 0 = 0 min 1..31 = 30..930 min
Clock_Value_ Status1 bit 1-0 r-00	Reserved

7 PROFIBUS DP Extensions

Clock_Sync-Buffer	
Clock_Value_ Status2 bit 7 r-0	ANH: Announcement Hour 0 = no change planned within the next hour 1 = a change of SWT will occur within the next hour
Clock_Value_ Status2 bit 6 r-0	SWT: Summertime 0 = Winter Time 1 = Summer Time
Clock_Value_ Status2 bit 5 r-0	Reserved
Clock_Value_ Status2 bit 4-3 r-00	CR: Accuracy 0 = 1 ms 1 = 10 ms 2 = 100 ms 3 = 1 s
Clock_Value_ Status2 bit 2-1 r-00	Reserved
Clock_Value_ Status2 bit 0 r-0	SYF: Synchronisation Active: 0 = Clock_Value_Time_Event is synchronized 1 = Clock_Value_Time_Event is not synchronized
r-0	Clock_Value_Time_Event: Same format as defined in IEC 61158-6 is used. Value is stored with the most significant byte at the lowest address. No address swapping is done for Intel format.
r-0	Receive_Delay_Time: Value is stored with the most significant byte in address 12. No address swapping is done for Intel format.
r-0	Clock_Value_previous_TE: Same format as defined in IEC 61158-6 is used. Value is stored with the most significant byte at the lowest address. No address swapping is done for Intel format.
rw-0	Clock_Sync_Interval: Value is stored with the most significant byte in address 24. No address swapping is done for Intel format.

Figure 7-29: Format of the Clock_Sync-Buffer




Figure 7-30: communication scheme

7 PROFIBUS DP Extensions

Notes:

8.1 Universal Processor Bus Interface

8.1.1 Overview

The VPC3+S can be interfaced by using either a parallel 8-bit data interface or an SPI or I2C interface.

In parallel mode the VPC3+S provides an 8-bit data interface with an 11-bit address bus. The VPC3+S supports all 8-bit processors and micro-controllers based on the 80C51/52 (80C32) from Intel, the Motorola HC11 family, as well as 8- /16-bit processors or microcontrollers from the Siemens 80C166 family, X86 from Intel and the HC16 and HC916 family from Motorola. Because the data formats from Intel and Motorola are different, VPC3+S automatically carries out 'byte swapping' for accesses to the following 16-bit registers (Interrupt Register, Status Register and Mode Register 0) and the 16-bit RAM cell (R_User_WD_Value). This makes it possible for a Motorola processor to read the 16-bit value correctly. Reading or writing takes place, as usual, through two accesses (8-bit data bus).

Four SPI modes are supported which differ in clock polarity and clock phase. In these interface modes the VPC3+S acts like a memory device with serial (SPI) interface connected to the CPU. The chip needs to be selected by pulling the Slave-Select pin (SPI_XSS) low before receiving clock pulses via SPI_SCK pin from the CPU. Depending on the OP-code received the VPC3+S carries out a read or write operation starting at the specified address inside the internal memory. Serial data is shifted in via SPI_MOSI pin and shifted out via SPI_MISO pin.

In I2C mode the VPC3+S can be connected to an I2C network by using the pins I2C_SCK and I2C_SDA. In this mode the VPC3+S acts like a memory device with serial (I2C) interface connected to the CPU. The chip supports slave mode only and the desired slave address can be selected by using the pins I2C_A[6:0]. Upon reception of the correct slave address and depending on the status of the R/W bit the VPC3+S carries out a read or write operation starting at the specified address inside the internal memory.

The Bus Interface Unit (BIU) and the Dual Port RAM Controller (DPC) that controls accesses to the internal RAM belong to the processor interface of the VPC3+S.

The VPC3+S is supplied with a clock pulse rate of 48MHz. In addition, a clock divider is integrated. The clock pulse is divided by 2 (Pin: DIVIDER = '1') or 4 (Pin: DIVIDER = '0') and applied to the pin CLKOUT. This allows the connection of a slower controller without additional expenditures in a low-cost application.

8 Hardware Interface

8.1.2 Parallel Interface Modes

The Bus Interface Unit (BIU) is the interface to the connected processor/microcontroller. This is a synchronous or asynchronous 8-bit interface with an 11-bit (12-bit in 4K Byte mode) address bus. The interface is configurable via 2 pins (XINT/MOT, MODE). The connected processor family (bus control signals such as XWR, XRD, or R_W and the data format) is specified with the XINT/MOT pin. Synchronous or asynchronous bus timing is specified with the MODE pin.

SERMODE	XINT/MOT	MODE	Processor Interface Mode
0	0	1	Synchronous Intel mode
0	0	0	Asynchronous Intel mode
0	1	0	Asynchronous Motorola mode
0	1	1	Synchronous Motorola mode

Figure 8-1: Configuration of the parallel Processor Interface Modes

Examples of various Intel system configurations are given in subsequent sections. The internal address latch and the integrated decoder must be used in the synchronous Intel mode. One figure shows the minimum configuration of a system with the VPC3+S, where the chip is connected to an EPROM version of the controller. Only a clock generator is necessary as an additional device in this configuration. If a controller is to be used without an integrated program memory, the addresses must be latched for the external memory.



Notes:

If the VPC3+S is connected to an 80286 or similar processor, it must be taken into consideration that the processor carries out word accesses. That is, either a 'swapper' is necessary that switches the characters out of the VPC3+S at the correct byte position of the 16-bit data bus during reading or the least significant address bit is not connected and the 80286 must read word accesses and evaluate only the lower byte.

Name	Input/Output	Type	Comments
DB(7..0)	I/O	Tristate	High-resistance during RESET
AB(10..0)	I		AB(10) has a pull down resistor.
MODE	I		Configuration: syn/async interface
XWR/E_CLOCK AB11	I		Intel: Write Sync. Motorola: E-Clk AB11 (Asynchronous Motorola Mode)
XRD/R_W	I		Intel: Read Motorola: Read/Write
XCS AB11	I		Chip Select AB11 (Synchronous Intel Mode)
ALE/AS AB11	I		Intel/Motorola: Address Latch Enable AB11 (Async. Intel / Sync. Motorola Mode)
DIVIDER	I		Scaling factor 2/4 for CLKOUT 2/4
X/INT	O	Push/Pull	Polarity programmable
XRDY/XDTACK	O	Push/Pull *	Intel/Motorola: Ready-Signal
CLK	I		48 MHz
XINT/MOT	I		Setting: Intel/Motorola
CLKOUT2/4	O	Push/Pull	24/12 MHz
RESET	I	Schmitt-Trigger	Minimum of 4 clock cycles

Figure 8-2: Microprocessor Bus Signals

* Due to compatibility reasons to existing competitive chips the XRDY/XDTACK output of the VPC3+S has push/pull characteristic (no tristate!).

Synchronous Intel Mode

In this mode Intel CPUs like 80C51/52/32 and compatible processor series from several manufacturers can be used.

- Synchronous bus timing without evaluation of the XREADY signal
- 8-bit multiplexed bus: ADB7..0
- The lower address bits AB7..0 are stored with the ALE signal in an internal address latch.
- The internal CS decoder is activated. VPC3+S generates its own CS signal from the address lines AB10..3. The VPC3+S selects the relevant address window from the AB2..0 signals.
- A11 from the microcontroller must be connected to XCS (pin 1) in 4K Byte mode as this is the additional address bus signal in this mode. In 2K Byte mode this pin is not used and should be pulled to VDD.

Asynchronous Intel Mode

In this mode various 16-/8-bit microcontroller series like Intel's x86, Siemens 80C16x or compatible series from other manufacturers can be used.

- Asynchronous bus timing with evaluation of the XREADY signal
- 8-bit non-multiplexed bus: DB7..0, AB10..0 (AB11..0 in 4K Byte mode)
- The internal VPC3+S address decoder is disabled, the XCS input is used instead.

8 Hardware Interface

- External address decoding is always necessary.
- External chip select logic is necessary if not present in the microcontroller
- A11 from the microcontroller must be connected to ALE/AS (pin 24) in 4K Byte mode as this is the additional address bus signal in this mode. In 2K Byte mode this pin is not used and should be pulled to GND.

Asynchronous Motorola Mode

Motorola microcontrollers like the HC16 and HC916 can be used in this mode. When using HC11 types with a multiplexed bus the address signals AB7..0 must be generated from the DB7..0 signals externally.

- Asynchronous bus timing with evaluation of the XREADY signal
- 8-bit non-multiplexed bus: DB7..0, (AB11..0 in 4K Byte mode)
- The internal VPC3+S address decoder is disabled, the XCS input is used instead.
- Chip select logic is available and programmable in all microcontrollers mentioned above.
- AB11 must be connected to XWR/E_CLOCK (pin 2) in 4K Byte mode as this is the additional address bus signal in this mode. In 2K Byte mode this pin is not used and should be pulled to GND.

Synchronous Motorola Mode

Motorola microcontrollers like the HC11 types K, N, M, F1 or the HC16- and HC916 types with programmable E_Clock timing can be used in this mode. When using HC11 types with a multiplexed bus the address signals AB7..0 must be generated from the DB7..0 signals externally.

- Synchronous bus timing without evaluation of the XREADY signal
- 8-bit non-multiplexed bus: DB7..0, AB10..0 (AB11..0 in 4K Byte mode)
- The internal VPC3+S address decoder is disabled, the XCS input is used instead.
- For microcontrollers with chip select logic (K, F1, HC16 and HC916), the chip select signals are programmable regarding address range, priority, polarity and window width in the write cycle or read cycle.
- For microcontrollers without chip select logic (N and M) and others, an external chip select logic is required. This means additional hardware and a fixed assignment.
- If the CPU is clocked by the VPC3+S, the output clock pulse (CLKOUT 2/4) must be 4 times larger than the E_Clock. That is, a clock pulse signal must be present at the CLK input that is at least 10 times larger than the desired system clock pulse (E_Clock). The Divider-Pin must be connected to '0' (divider 4). This results in an E_Clock of 3 MHz.
- AB11 must be connected to ALE/AS (pin 24) in 4K Byte mode as this is the additional address bus signal in this mode. In 2K Byte mode this pin is not used and should be pulled to GND.

8.1.3 SPI Interface Mode

The VPC3+S is designed to interface directly with the Serial Peripheral Interface (SPI) port of many of today's popular microcontroller families. It may also interface with microcontrollers that do not have a built-in SPI port by using discrete I/O lines programmed to match the SPI protocol.

The SPI mode allows a duplex, synchronous, serial communication between the CPU and peripheral devices. The CPU is always master while the VPC3+S is always slave in this configuration.

Four associated SPI port pins are dedicated to the SPI function as as:

- Slave-Select (SPI_XSS)
- Serial Clock (SPI_SCK)
- Master-Out-Slave-In (SPI_MOSI)
- Master-In-Slave-Out (SPI_MISO)

The clock phase control bit (SPI_CPHA) and the clock polarity control bit (SPI_CPOL) select one of four possible clock formats to be used by the SPI system. The CPOL bit simply selects a non-inverted or inverted clock. The CPHA bit is used to accommodate two fundamentally different protocols by sampling data on odd numbered SCK edges (SPI_CPHA='0') or on even numbered SCK edges (SPI_CPHA='1').

The main element of the SPI system is the SPI Data Register. The 8-bit data register in the master and the 8-bit data register in the slave are linked by the MOSI and MISO pins to form a distributed 16-bit register. When a data transfer operation is performed, this 16-bit register is serially shifted eight bit positions by the SCK clock from the master, so data is exchanged between the master and the slave.




Figure 8-3: SPI Master-Slave-Transfer (Block Diagram)

8 Hardware Interface

Data written to the master SPI Data Register becomes the output data for the slave, and data read from the master SPI Data Register after a transfer operation is the input data from the slave.

Transmission Formats

During an SPI transmission, data is transmitted (shifted out serially) and received (shifted in serially) simultaneously. The serial clock (SCK) synchronizes shifting and sampling of the information on the two serial data lines. The slave select line allows selection of an individual slave SPI device, slave devices that are not selected do not interfere with SPI bus activities.

The **CPOL** clock polarity control bit specifies an active high or low clock and has no significant effect on the transmission format. The **CPHA** clock phase control bit selects one of two fundamentally different transmission formats. Clock phase and polarity should be identical for the master SPI device and the communicating slave device.

CPHA = 0 Transfer Format

The first edge on the SCK line is used to clock the first data bit of the slave into the master and the first data bit of the master into the slave. In some peripherals, the first bit of the slave's data is available at the slave's data out pin as soon as the slave is selected. In this format, the first SCK edge is issued a half cycle after SS has become low.

A half SCK cycle later, the second edge appears on the SCK line. When this second edge occurs, the value previously latched from the serial data input pin is shifted into the shift register.




Figure 8-4: SPI Transfer Format (CPHA=0')

After this second edge, the next bit of the SPI master data is transmitted out of the serial data output pin of the master to the serial input pin on the slave. This process continues for a total of 16 edges on the SCK line, with data being latched on odd numbered edges and shifted on even numbered edges.

Data reception is double buffered. Data is shifted serially into the SPI shift register during the transfer and is transferred to the parallel SPI Data Register after the last bit is shifted in.

CPHA = 1 Transfer Format

Some peripherals require the first SCK edge before the first data bit becomes available at the data out pin, the second edge clocks data into the system. In this format, the first SCK edge is issued by setting the CPHA bit at the beginning of the 8-cycle transfer operation.

The first edge of SCK occurs immediately after the half SCK clock cycle synchronization delay. This first edge commands the slave to transfer its first data bit to the serial data input pin of the master.

A half SCK cycle later, the second edge appears on the SCK pin. This is the latching edge for both the master and slave.

When the third edge occurs, the value previously latched from the serial data input pin is shifted into the SPI shift register. After this edge, the next bit of the master data is coupled out of the serial data output pin of the master to the serial input pin on the slave.




Figure 8-5: SPI Transfer Format (CPHA='1')

8 Hardware Interface

This process continues for a total of 16 edges on the SCK line with data being latched on even numbered edges and shifting taking place on odd numbered edges.

Data reception is double buffered, data is serially shifted into the SPI shift register during the transfer and is transferred to the parallel SPI Data Register after the last bit is shifted in.

Principles of Operation

The VPC3+S contains an 8-bit instruction register and a 16-bit address register. The device is accessed via the MOSI pin, with data being clocked in on the configured edge of SCK. The XSS pin must be held low for the entire operation.

The first byte received during a valid SPI transfer is interpreted as SPI instruction. Figure 8-6 lists the supported instruction bytes and formats for the device operation. All instructions, addresses, and data are transferred MSB first, LSB last.

Instruction Name	Instruction Format	Description
READ BYTE	0001 0011	Read a single data byte from selected address
READ ARRAY	0000 0011	Read several data bytes beginning at selected address (with auto-increment)
WRITE BYTE	0001 0010	Write a single data byte to selected address
WRITE ARRAY	0000 0010	Write several data bytes beginning at selected address (with auto-increment)

Figure 8-6: SPI Instruction Set



Note:

In SPI interface mode all internal addresses are interpreted in Intel format. Motorola format (byte swapping for certain addresses) is not supported in SPI mode.

READ BYTE Sequence

The device is selected by pulling XSS low. The 8-bit READ BYTE instruction is transmitted to the VPC3+S followed by the 16-bit address, with the four MSBs of the address being “don’t care” bits (in case of 2 kB RAM mode the five MSBs of the address are “don’t care”).

After the correct READ BYTE instruction and address are sent, the data byte stored in the memory at the selected address is shifted out on the MISO pin. After additional 8 SCK pulses the complete data byte has sent and no more valid data bits are shifted out on the MISO pin. There is no auto-increment mechanism for this instruction. The read operation is terminated by raising the XSS pin (Figure 8-7).



Note:

When reading from the Control Parameter memory (address 0x000 to address 0x015) only the READ BYTE instruction may be used. Otherwise an unintended read operation to the subsequent memory location will occur leading to an unpredictable behavior of the VPC3+S.




Figure 8-7: READ BYTE Sequence

READ ARRAY Sequence

The device is selected by pulling XSS low. The 8-bit READ BYTE instruction is transmitted to the VPC3+S followed by the 16-bit address, with the four MSBs of the address being “don’t care” bits (in case of 2 kB RAM mode the five MSBs of the address are “don’t care”).

After the correct READ ARRAY instruction and address are sent, the data byte stored in the memory at the selected address is shifted out on the MISO pin. After additional 8 SCK pulses the complete first data byte has been sent. The data byte stored in the memory at the next address can be read sequentially by continuing to provide clock pulses. The internal Address Pointer is automatically incremented to the next higher address after each byte of data is shifted out. When the highest address is reached (0x7FF in case of 2 kB RAM mode or 0xFFF in 4 kB mode), the address counter rolls over to address 0x000 allowing the read cycle to be continued indefinitely. The read operation is terminated by raising the XSS pin (Figure 8-8).



Note:

The SPI instruction READ ARRAY may not be used when reading from the Control Parameter memory (address 0x000 to address 0x015). Otherwise (due to the auto-increment mechanism of the READ ARRAY instruction) an unintended read operation to the subsequent memory location will occur leading to an unpredictable behavior of the VPC3+S.

8 Hardware Interface




Figure 8-8: READ ARRAY Sequence

WRITE BYTE Sequence

The VPC3+S is selected by pulling XSS low. The 8-bit WRITE BYTE instruction is transmitted to the device followed by the 16-bit address, with the four MSBs of the address being “don’t care” bits (in case of 2 kB RAM mode the five MSBs of the address are “don’t care”).

After the correct WRITE BYTE instruction and address are sent, the data byte is shifted in on the MOSI pin. Once 8 SCK clock pulses are received the sampled data byte is written to the selected address. Providing more SCK clock pulses does not affect the VPC3+S. The write operation is terminated by raising the XSS pin.




Figure 8-9: WRITE BYTE Sequence

WRITE ARRAY Sequence

The WRITE ARRAY sequence is similar to the WRITE BYTE sequence unless more than one data byte is transferred. After the reception of every data byte the internal destination address is auto-incremented by '1'. When the highest address is reached (0x7FF in case of 2 kB RAM mode or 0xFFF in 4 kB mode), the address counter rolls over to address 0x000 allowing the write cycle to be continued indefinitely. The write operation is terminated by raising the XSS pin.




Figure 8-10: WRITE ARRAY Sequence

8.1.4 I2C Interface Mode

The VPC3+S supports a bidirectional, 2-wire bus and data transmission protocol. A device that sends data onto the bus is defined as transmitter, while a device receiving data is defined as a receiver. The bus has to be controlled by a master device which generates the Serial Clock (SCK), controls the bus access and generates the Start and Stop conditions, while the VPC3+S works as slave. Both master and slave can operate as transmitter or receiver, but the master device determines which mode is activated.

The data on the SDA line must be stable during the HIGH period of the clock. The HIGH or LOW state of the data line can only change when the clock signal on the SCK line is LOW (Figure 8-11). One clock pulse is generated for each data bit transferred.

8 Hardware Interface




Figure 8-11: Bit Transfer on the I2C bus

All transactions begin with a START (S) and can be terminated by a STOP (P) condition. A HIGH to LOW transition on the SDA line while SCK is HIGH defines a START condition. A LOW to HIGH transition on the SDA line while SCK is HIGH defines a STOP condition.




Figure 8-12: START and STOP condition

START and STOP conditions are always generated by the master. The bus is considered to be busy after the START condition. The bus is considered to be free again a certain time after the STOP condition.

Every byte sent on the SDA line must be 8 bits long. The number of bytes that can be transmitted per transfer is unrestricted. Each byte has to be followed by an Acknowledge bit. Data is transferred with the Most Significant Bit (MSB) first.




Figure 8-13: Data Transfer on the I2C Bus

Each receiving device, when addressed, is obliged to generate an Acknowledge after the reception of each byte. The master device must generate an extra clock pulse which is associated with this Acknowledge bit. The device that acknowledges, has to pull down the SDA line during the acknowledge clock pulse in such a way that the SDA line is stable low during the high period of the acknowledge related clock pulse. Of course, setup and hold times must be taken into account. During reads, a master must signal an end of data to the slave by not generating an Acknowledge bit on the last byte that has been clocked out of the slave. In this case, the slave (VPC3+S) will leave the data line high to enable the master to generate the Stop condition.

A control byte is the first byte received following the Start condition from the master device (Figure 8-14). The control byte consists of a seven-bit Slave Address SA[6:0] to select which device is accessed. The Slave Address bits in the control byte must correspond to the logic levels on the I2C_SA[6:0] pins for the VPC3+S to respond.




Figure 8-14: Control Byte Format

The last bit of the control byte defines the operation to be performed. When set to a '1', a read operation is selected. When set to a '0', a write operation is selected.

The next two bytes received define the address of the first data byte (Figure 8-15). In case of the 4 kB RAM mode is selected only A11 to A0 are used, the upper four address bits are "don't care" bits (in case of 2 kB RAM mode the upper five address bits are "don't care").

The upper address bits (MSB) are transferred first, followed by the Less Significant bits (LSB). Following the Start condition, the VPC3+S monitors the SDA line checking the control byte transmitted and, upon receiving appropriate Slave Address bits, the device outputs an Acknowledge signal on the SDA line. Depending on the state of the R/W bit, the VPC3+S will select a read or write operation.




Figure 8-15: Address Sequence Bit Assignments

WRITE Sequence

Following the START condition from the master, Slave Address (6 bits) and the R/W bit (which is a logic low) are clocked onto the bus by the master transmitter. This indicates to the addressed slave receiver that the address high byte will follow once it has generated an Acknowledge bit during the ninth clock cycle. Therefore, the next byte transmitted by the master is the high-order byte of the address and will be written into the Address Pointer of the VPC3+S. The next byte is the Least Significant Address Byte. After receiving another Acknowledge signal from the VPC3+S, the master device will transmit the data byte to be written into the addressed memory location. The VPC3+S acknowledges again and the master either generates a STOP condition or transfers more data bytes to the VPC3+S. Upon receipt of each data byte, the VPC3+S generates an Acknowledge signal and the internal Address Pointer is incremented by '1'. When the highest address is reached (0x7FF in case of 2 kB RAM mode or 0xFFF in 4 kB mode), the address counter rolls over to address 0x000 allowing the write sequence to be continued indefinitely. The write operation is terminated by receiving a STOP condition from the master.




Figure 8-16: I2C WRITE Sequence

READ Operations

Read operations are initiated in the same way as write operations, with the exception that the R/W bit of the control byte is set to '1'. There are three basic types of read operations: current address read, random read and sequential read.

Current Address READ Operation

The VPC3+S contains an address counter that maintains the address of the last byte accessed, internally incremented by '1'. Therefore, if the previous read access was to address 'n' (n is any legal address), the next current address read operation would access data from address $n + 1$.

Upon receipt of the control byte with R/W bit set to '1', the VPC3+S issues an acknowledge and transmits the 8-bit data byte. The master will not acknowledge the transfer, but does generate a STOP condition and the VPC3+S discontinues transmission.




Figure 8-17: I2C Current Address READ Operation

Random READ Operation

Random read operations allow the master to access any memory location in a random manner. To perform this type of read operation, the byte address must first be set. This is accomplished by sending the byte address to the VPC3+S as part of a write operation (R/W bit set to '0'). Once the byte address is sent, the master generates a START condition following the acknowledge. This terminates the write operation, but not before the internal Address Pointer is set. The master issues the control byte again, but with the R/W bit set to a '1'. The VPC3+S will then issue an acknowledge and transmit the 8-bit data byte. The master will not acknowledge the transfer, but does generate a Stop condition which causes the VPC3+S to discontinue transmission (Figure 8-17). After a random Read command, the internal address counter will point to the address location following the one that was just read.




Figure 8-18: I2C Random READ Operation

Sequential READ Operation

Sequential reads are initiated in the same way as a random read, except that once the VPC3+S transmits the first data byte, the master issues an acknowledge as opposed to the Stop condition used in a random read. This acknowledge directs the VPC3+S to transmit the next sequentially addressed data byte (Figure 8-19). Following the final byte transmitted to the master, the master will NOT generate an acknowledge, but will generate a STOP condition. To provide sequential reads, the VPC3+S contains an internal Address Pointer which is incremented by '1' upon completion of each operation. This Address Pointer allows the entire memory contents to be serially read during one operation. The internal

8 Hardware Interface

Address Pointer will automatically roll over from address 0xFFF (0x7FF in 2 kB mode) to address 0x000 if the master acknowledges the byte received from address 0xFFF (0x7FF).




Figure 8-19: I2C Sequential READ Operation

8.1.5 Application Examples (Principles)




Figure 8-20: Low Cost System with 80C32




Figure 8-21: 80C32 System with External Memory

8 Hardware Interface




Figure 8-22: 80286 System (X86 Mode)

8.1.6 Application with 80C32 (2K Byte RAM Mode)




Figure 8-23: 80C32 Application in 2K Byte mode

The internal chipselect is activated when the address inputs AB[10..3] of the VPC3+S are set to '0'. In the example above the start address of the VPC3+S is set to 1000H.




Figure 8-24: Internal Chipselect Generation in Synchronous Intel Mode, 2K Byte RAM

8 Hardware Interface

8.1.7 Application with 80C32 (4K Byte RAM Mode)




Figure 8-25: 80C32 Application in 4K Byte mode

The internal chipselect is activated when the address inputs AB[10..3] of the VPC3+S are set to '0'. In the example above the start address of the VPC3+S is set to 2000H.




Figure 8-26 : Internal Chipselect Generation in Synchronous Intel Mode, 4K Byte RAM

8.1.8 Application with 80C165




Figure 8-27: 80C165 Application

8.2 Dual Port RAM Controller

The internal 4K Byte RAM of the VPC3+S is a single-port RAM. An integrated Dual-Port RAM controller, however, permits an almost simultaneous access of both ports (bus interface and microsequencer interface). When there is a simultaneous access of both ports, the bus interface has priority. This guarantees the shortest possible access time. If the VPC3+S is connected to a microcontroller with an asynchronous interface, the controller can evaluate the Ready signal.

8 Hardware Interface

8.3 UART

The transmitter converts the parallel data structure into a serial data flow. Signal Request-to-Send (RTS) is generated before the first character. The XCTS input is available for connecting a modem. After RTS active, the transmitter must hold back the first telegram character until the modem activates XCTS. XCTS is checked again after each character.

The receiver converts the serial data flow into the parallel data structure and scans the serial data flow with the four-fold transmission speed. Stop bit testing can be switched off for test purposes ('Dis_Stop_Control = 1' in Mode Register 0 or Set_Prm telegram for DP). One requirement of the PROFIBUS protocol is that no rest states are permitted between the telegram characters. The VPC3+S transmitter ensures that this specification is maintained.

The synchronization of the receiver starts with the falling edge of the start bit. The start bit is checked again in the middle of the bit-time for low level. The data bits, the parity and the stop bit are also scanned in the middle of the bit-time. To compensate for the synchronization error, a repeater generates a $\pm 25\%$ distortion of the stop bit at a four-fold scan rate. In this case the VPC3+ should be parameterized with 'Dis_Start_Control = 1' (in Mode Register 0 or Set_Prm telegram for DP) in order to increase the permissible distortion of the stop bit.

8.4 ASIC Test

All output pins and I/O pins can be switched to the high-resistance state via the XTEST0 test pin. An additional XTEST1 input is provided to test the chip on automatic test devices (not in the target hardware environment!).

Pin	Name	Value	Function
D2	XTEST0	GND	All outputs high-resistance
		VCC	Normal VPC3+ function
E5	XTEST1	GND	Various test modes
		VCC	Normal VPC3+ function

Figure 8-28: Test Ports

9.1 Pin Assignment

The data transmission is performed in RS485 operating mode (i.e., physical RS485). The VPC3+S is connected via the following signals to the galvanically isolated interface drivers.

Signal Name	Input/Output	Function
RTS	Output	Request to send
TXD	Output	Sending data
RXD	Input	Receiving data

Figure 9-1: PROFIBUS Signals

The PROFIBUS interface is a 9-way, sub D, plug connector with the following pin assignment.

- Pin 1 - Free
- Pin 2 - Free
- Pin 3 - B line
- Pin 4 - Request to send (RTS)
- Pin 5 - Ground 5V (M 5)
- Pin 6 - Potential 5V (floating P5)
- Pin 7 - Free
- Pin 8 - A line
- Pin 9 - Free

The cable shield must be connected to the plug connector housing. The free pins are described as optional in IEC 61158-2.



CAUTION:

The pin names A and B on the plug connector refer to the signal names in the RS485 standard and not the pin names of driver ICs.

Keep the wires from driver to connector as short as possible.

9 PROFIBUS Interface

9.2 Example for the RS485 Interface

To minimize the capacity of the bus lines the user should avoid additional capacities. The typical capacity of a bus station should be 15...25 pF.




Figure 9-2: Example for the RS485 Interface

Operational Specifications 10

10.1 Absolute Maximum Ratings

Parameter	Symbol	Limits	Unit
DC supply voltage	VCC	-0.3 to 3.9	V
Input voltage	V _I	-0.3 to 5.5	V
Output voltage	V _O	-0.3 to VCC +0.3	V
DC output current	I _O	See Figure 10-4	mA
Storage temperature	T _{store}	-40 to +150	°C

Figure 10-1: Absolute Maximum Ratings

10.2 Recommended Operating Conditions

Parameter	Symbol	MIN	MAX	Unit
DC supply voltage	VCC	3.00	3.6	V
Static supply current	I _{cc}		100 ¹⁾	µA
Circuit ground	GND	0	0	V
Input voltage	V _I	0	5.50	V
Input voltage (HIGH level)	V _{IH}	2.00	5.50	V
Input voltage (LOW level)	V _{IL}	0	0.8	V
Output voltage	V _O	0	VCC	V
Ambient temperature	T _A	-40	+85	°C

¹⁾: Static I_{DD} current is exclusively of input/output drive requirements and is measured with the clock stopped and all inputs tied to VCC or GND.

Figure 10-2: Recommended Operating Conditions

10.3 General DC Characteristics

Parameter	Symbol	MIN	TYP	MAX	Unit
Input LOW current	I _{IL}	-1		+1	µA
Input HIGH current	I _{IH}	-1		+1	µA
Tri-state leakage current	I _{OZ}	-10		+10	µA
Current consumption (3.3V)	I _A		30		mA
Input capacitance	C _{IN}		5		pF
Output capacitance	C _{OUT}		5		pF
Bi-directional buffer capacitance	C _{BID}		5		pF
Thermal Resist. (BGA48)	Θ _{JA}		43.6		K/W
Thermal Resist. (QFP48)	Θ _{JA}		72.2		K/W

Figure 10-3: General DC Characteristics

10 Operational Specifications

10.4 Ratings for the Output Drivers

Signal	Direction	Driver Type	Driver Strength	Max. Cap. Load
DB 0-7	I/O	Tristate	8mA	50pF
RTS	O	Push/Pull	8mA	50pF
TXD	O	Tristate	8mA	50pF
INT	O	Push/Pull	8mA	50pF
XREADY/XDTACK SPI_MISO I2C_SDA	O O I/O	Push/Pull Push/Pull Tristate	8mA	50pF
XDATAEXCH	O	Push/Pull	8mA	50pF
CLKOUT	O	Push/Pull	8mA	50pF

Figure 10-4: Ratings for the Output Drivers

10.5 DC Electrical Characteristics

Parameter	Symbol	MIN	TYP	MAX	Unit
DC supply voltage	VCC	3.00	3.30	3.60	V
Input voltage LOW level	V _{IL}			0.8	V
Input voltage HIGH level	V _{IH}	2.0			V
Output voltage LOW level	V _{OL}			0.4	V
Output voltage HIGH level	V _{OH}	2.4			V
Schmitt Trigger negative going threshold voltage	V _{T-}	0.9	1.1		V
Schmitt Trigger positive going threshold voltage	V _{T+}		1.6	1.9	V
Input LOW current	I _{IL}	-1		+1	μA
Input HIGH current	I _{IH}	-1		+1	μA
Tri-state leakage current	I _{oz}	-10	±1	+10	μA
Output current LOW level, 8mA cell	I _{oL}	+8			mA
Output current HIGH level, 8mA cell	I _{oH}	-8			mA

Figure 10-5: DC Specification of I/O Drivers for 3.3V Operation



Notes:

The VPC3+S is equipped with 5V tolerant inputs.

10.6 Timing Characteristics

All signals beginning with 'X' are 'low active'. All timing values are based on the capacitive loads specified in the table above.

10.6.1 System Bus Interface

Clock

Clock frequency is 48 MHz. Distortion of the clock signal is permissible up to a ratio of 30:70 at the threshold levels 0.9 V and 2.1 V.

Parameter	Symbol	MIN	MAX	Unit
Clock period	T	20.83	20.83	
Clock high time	T _{CH}	6.25	14.6	ns
Clock low time	T _{CL}	6.25	14.6	ns
Clock rise time	T _{CR}		4	ns
Clock fall time	T _{CF}		4	ns

Figure 10-6: Clock Timing



Note:

The VPC3+S is equipped with 5V tolerant inputs.

Interrupt:

After acknowledging an interrupt with EOI, the interrupt output of the VPC3+S is deactivated for at least 1 μ s or 1 ms depending on the bit EOI_Time_Base in Mode Register 0.

Parameter	MIN	MAX	Unit
Interrupt inactive time EOI_Timebase = '0'	1	1	μ s
Interrupt inactive time EOI_Timebase = '1'	1	1	ms

Figure 10-7: End-of-Interrupt Timing

Reset:

VPC3+S requires a minimum reset phase of 100 ns at power-on.

10 Operational Specifications

10.6.2 Timing in the Synchronous Intel Mode

In the synchronous Intel mode, the VPC3+S latches the least significant addresses with the falling edge of ALE. At the same time, the VPC3+S expects the most significant address bits on the address bus. An internal chipselect signal is generated from the most significant address bits. The request for an access to the VPC3+S is generated from the falling edge of the read signal (XRD) and from the rising edge of the write signal (XWR).




Figure 10-8: Synchronous Intel Mode, READ (XWR = 1)




Figure 10-9: Synchronous Intel Mode, WRITE (XRD = 1)

No.	Parameter	MIN	MAX	Unit
1	ALE pulsewidth	10		ns
2	ALE ↓ to XRD ↓	20		ns
3	Address to ALE ↓ setuptime	10		ns
4	Address holdtime after ALE ↓	0		ns
5	XRD ↓ to data valid		83	ns
6	XRD pulsewidth	105		ns
7	XRD ↑ to ALE ↑	10		ns
8	address (AB7..0) holdtime after XRD/XWR ↑	0		ns
9	data holdtime after XRD ↑	3	12	ns
10	XRD / XWR cycletime	155		ns
11	ALE ↓ to XWR ↓	20		ns
12	XWR pulsewidth	83		ns
13	data setuptime to XWR ↑	10		ns
14	XWR ↑ to ALE ↑	10		ns
15	data holdtime after XWR ↑	0		ns

Figure 10-10: Timing, Synchronous Intel Mode

10 Operational Specifications

10.6.3 Timing in the Asynchronous Intel Mode

In the asynchronous Intel mode, the VPC3+S acts like a memory with ready logic. The access time depends on the type of access. The request for an access to the VPC3+S is generated from the falling edge of the read signal (XRD) or the rising edge of the write signal (XWR).

The VPC3+S generates the Ready signal synchronously to the system clock. The Ready signal gets inactive when the read or the write signal is deactivated. The data bus is switched to Tristate with $XRD = '1'$.




Figure 10-11: Asynchronous Intel Mode, READ ($XWR = 1$)




Figure 10-12: Asynchronous Intel Mode, WRITE (XRD = 1)

No.	Parameter	MIN	MAX	Unit
16	address-setuptime to XRD / XWR ↓	0		ns
17	XRD ↓ to data valid		83	ns
18	XRD pulsewidth	105		ns
19	XCS ↓ setuptime to XRD / XWR ↓	0		ns
20	XRD ↓ to XREADY ↓ (Normal-Ready)		125	ns
21	XRD ↓ to XREADY ↓ (Early-Ready)		104	ns
22	XRD / XWR cycletime	125		ns
23	address holdtime after XRD / XWR ↑	0		ns
24	data holdtime after XRD ↑	3	12	ns
25	read/write inactive time	10		ns
26	XCS holdtime after XRD / XWR ↑	0		ns
27	XREADY holdtime after XRD / XWR	3	15	ns
28	data setuptime to XWR ↑	10		ns
29	XWR pulsewidth	83		ns
30	data holdtime after XWR ↑	0		ns

Figure 10-13: Timing, Asynchronous Intel Mode

10 Operational Specifications

10.6.4 Timing in the Synchronous Motorola Mode

If the CPU is clocked by the VPC3+S, the output clock pulse (CLKOUT 2/4) must be 4 times larger than the E_Clock. That is, a clock pulse signal must be present at the CLK input that is at least 10 times larger than the desired system clock pulse (E_Clock). The Divider-Pin must be connected to '0' (divider 4). This results in an E_Clock of 3 MHz.

The request for a read access to the VPC3+S is derived from the rising edge of the E_Clock (in addition: XCS = 0, R_W = 1). The request for a write access is derived from the falling edge of the E_Clock (in addition: XCS = 0, R_W = 0).




Figure 10-14: Synchronous Motorola-Mode, READ (AS = 1)




Figure 10-15: Synchronous Motorola-Mode, WRITE (AS = 1)

No.	Parameter	MIN	MAX	Unit
31	E_Clock pulse width	136.7		ns
33	Address setup time (A10..0) to E_Clock ↑	10		ns
37	Address holdtime after E_Clock ↓	0		ns
32	E_Clock ↑ to Data valid		83	ns
38	Data holdtime after E_Clock ↓	3	12	ns
35	R_W setup time to E_Clock ↑	10		ns
39	R_W holdtime after E_Clock ↓	5		ns
36	XCS setup time to E_Clock ↑	0		ns
40	XCS holdtime after E_Clock ↓	0		ns
41	Data setup time to E_Clock ↓	10		ns
42	Data holdtime after E_Clock ↓	0		ns

Figure 10-16: Timing, Synchronous Motorola Mode

10 Operational Specifications

10.6.5 Timing in the Asynchronous Motorola Mode

In the asynchronous Motorola mode, the VPC3+S acts like a memory with Ready logic, whereby the access times depend on the type of access.

The request for an access of the VPC3+S is generated from the falling edge of the AS signal (in addition: XCS = '0', R_W = '1'). The request for a write access is generated from the rising edge of the AS signal (in addition: XCS = '0', R_W = '0').




Figure 10-17: Asynchronous Motorola Mode, READ (E_CLOCK = 0)




Figure 10-18: Asynchronous Motorola Mode (WRITE)

10 Operational Specifications

No.	Parameter	MIN	MAX	Unit
43	address setup time to AS ↓	0		ns
44	AS ↓ to data valid		83	ns
45	AS pulsewidth (read access)	115		ns
46	R_W ↓ setup time to AS ↓	10		ns
47	XCS ↓ setup time to AS ↓	5		ns
48	AS ↓ to XDTACK ↓ (Normal-Ready)		125	ns
49	AS ↓ to XDTACK ↓ (Early-Ready)		104	ns
50	last AS ↓ to XCS ↓	93		ns
51	AS cycle time	125		ns
52	address hold time after AS ↑	0		ns
53	Data hold time after AS ↑	3	12	ns
54	AS inactive time	10		ns
55	R_W hold time after AS ↑	10		ns
56	XCS hold time after AS ↑	0		ns
57	XDTACK hold time after AS ↑	3	15	ns
58	Data setup time to AS ↑	10		ns
59	AS pulsewidth (write access)	83		ns
60	Data hold time after AS ↑	0		ns

Figure 10-19: Timing, Asynchronous Motorola Mode

10.6.6 Timing in SPI Interface Mode




Figure 10-20: Timing Diagram SPI Interface Mode (CPHA='0')




Figure 10-21: Timing Diagram SPI Interface Mode (CPHA='1')

10 Operational Specifications

Symbol	Parameter	MIN	MAX	Unit
f_{SCK}	Clock Frequency, SCK		6	MHz
$t_{LOW.SCK}$	Clock Pulse Width Low	83		ns
$t_{HIGH.SCK}$	Clock Pulse Width High	83		ns
$t_{S.XSS}$	XSS Setup Time	83		ns
$t_{V.SO}$	Clock to Data Out Valid		76	ns
$t_{H.SO}$	Data Out Hold Time	21		ns
$t_{S.SI}$	Data In Set-up Time	10		ns
$t_{H.SI}$	Data In Hold Time	10		ns
$t_{DIS.SO}$	Output Disable Time		83	ns
$t_{HIGH.XSS}$	XSS Inactive (High) Time	83		ns

Figure 10-22: Timing, SPI Interface Mode

10.6.7 Timing in I2C Interface Mode




Figure 10-23: Timing Diagram I2C Interface Mode

Symbol	Parameter	MIN	MAX	Unit
f_{SCK}	Clock Frequency, SCK		6	MHz
t_{LOW}	Clock Pulse Width Low	83		ns
t_{HIGH}	Clock Pulse Width High	83		ns
t_{AA}	Clock Low to Data Out Valid		76	ns
$t_{H.STA}$	Start Condition Hold Time	21		ns
$t_{S.STA}$	Start Condition Set-up Time	21		ns
$t_{H.DAT}$	Data In Hold Time	10		ns
$t_{S.DAT}$	Data In Set-up Time	10		ns
$t_{S.STO}$	Stop Condition Set-up Time	21		ns
t_{DH}	Data Out Hold Time	21		ns

Figure 10-24: Timing, I2C Interface Mode

10 Operational Specifications

10.7 Package Specifications

10.7.1 LFBGA48





Figure 10-25: LFBGA48 Package Drawing



		Symbol	Common Dimensions
Package :			LF BGA
Body Size:	X	E	6.000
	Y	D	8.000
Ball Pitch :	X	eE	0.800
	Y	eD	0.800
Total Thickness :		A	1.400 MAX.
Mold Thickness :		M	0.530 Ref.
Substrate Thickness :		S	0.360 Ref.
Ball Diameter :			0.450
Stand Off :		A1	0.250~0.400
Width :		b	0.400~0.500
Package Edge Tolerance :		aaa	0.150
Mold Flatness :		bbb	0.200
Coplanarity:		ddd	0.150
Ball Offset (Package) :		eee	0.150
Ball Offset (Ball) :		fff	0.080
Ball Count :		n	48
Edge Ball Center to Center :	X	E1	4.000
	Y	D1	5.600

Figure 10-26 : LFBGA48 Package Dimensions and Tolerances

10 Operational Specifications

10.7.2 LQFP48




Figure 10-27: LQFP48 Package Drawing

Symbol	Dimensions in mm		
	MIN	NOM	MAX
A			1.60
A ₁	0.05		0.15
A ₂	1.35	1.40	1.45
b	0.17	0.22	0.27
b ₁	0.17	0.20	0.23
c	0.09		0.20
c ₁	0.09		0.16
D	9.00 BSC		
D ₁	7.00 BSC		
E	9.00 BSC		
E ₁	7.00 BSC		
e	0.50 BSC		
L	0.45	0.60	0.75
L ₁	1.00 REF		
R ₁	0.08		
R ₂	0.08		0.20
S	0.20		
Θ	0°	3.5°	7°
Θ ₁	0°		
Θ ₂	12° TYP		
Θ ₃	12° TYP		

Figure 10-28 : LQFP48 Package Dimensions and Tolerances

10 Operational Specifications

10.8 Processing Instructions

Generally, ESD protective measures must be maintained for all electronic components. The VPC3+S is a cracking-endangered component that must be handled properly.

Profichip products are tested and classified for moisture sensitivity according to the procedures outlined by JEDEC. The VPC3+S is classified as moisture sensitivity level (MSL) 3.



In order to minimize any potential risk caused by moisture trapped inside non-hermetic packages it is a general recommendation to perform a drying process before soldering.

10.9 Ordering Information

Version	Order Code	Package	Temperature Range	Notes
VPC3+S-BGA48	PALF2009	LFBGA48	Industrial (-40°C to +85°C)	
VPC3+S-QFP48	PALF2012	LQFP48	Industrial (-40°C to +85°C)	

Revision History

Version	Date	Page	Remarks
V1.00	01.04.2009		First release
V1.01	10.08.2009	29 72-77 96 111	Description of GC_Int_Mode_Ext in Mode Register 3 corrected Some hints for configuration of PLL added Name of I2C clock changed from SCL to SCK Current consumption and thermal resistance added
V1.02	25.05.2010	92 95	SPI instruction "WRITE ARRAY" added to Figure 8-6 Instruction coding in Figure 8-10 "WRITE ARRAY Sequence" corrected
V1.03	28.05.2010	122 123	Timing table for SPI interface mode corrected (MIN/MAX values swapped) Timing table for I2C interface mode corrected (MIN/MAX values swapped)
V1.04	10.10.2012	10-17 111 128-129 130	Pin assignment of LQFP48 package version added Thermal resistance of LQFP48 package added LQFP48 package drawing added Processing instructions revised and ordering information added

profichip GmbH
Einsteinstrasse 6
91074 Herzogenaurach
Germany

Phone : +49.9132.744-200
Fax: +49.9132.744-2164

www.profichip.com

